

# **Water System Asset Management Program Newport, New Hampshire**

**May 24, 2019**



2382

Prepared by:



## Table of Contents

1. Introduction .....	3
2. Asset Inventory and Condition Assessment .....	4
2.1. Condition Assessment .....	4
2.2. Data History, Information Sources and Organization .....	5
2.3. Replacement Value of Water System.....	5
3. Level of Service .....	8
3.1. Leaks and Water Main Breaks .....	8
3.2. Data and Follow-up .....	8
3.3. Financial Resources.....	8
4. Critical Assets and Priority Projects .....	10
5. Minimum Life Cycle Cost (Practices) .....	12
6. Long Term Funding Plan (Budget) .....	15
7. Implementation and Communication Plan .....	18
8. Conclusions and Recommendations .....	20

## Tables

Table 1: Water System Summary .....	4
Table 2. Water Distribution Pipe by Age and Material .....	6
Table 3. Pipe by Remaining Useful Life .....	8
Table 4. Impact of Affordability on SRF Loan Application Evaluation .....	12
Table 5. Estimated Replacement Costs - Ten Years.....	12
Table 6. Estimated Replacement Costs by Risk Score – Ten Years.....	13
Table 7. Estimated Asset Renewals per Year for the Next 50 Years .....	13
Table 8. Estimated Replacement Costs – Next 100 Years.....	15

## Figures

Figure 1. Overall Replacement Value.....	5
Figure 2. Replacement Value of Vertical Assets .....	7
Figure 3. Criticality Matrix .....	11
Figure 4. Water Use and Revenue (2018 Rate Study) .....	14
Figure 5. Estimated Replacement Costs – Next 100 Years .....	16
Figure 6. Implementation Flow Chart.....	18
Figure 7. Communication Flow Chart .....	19



## Appendices

### **A. Financial Information**

- A-1. SRF Intended Use Plan Excerpts
- A-2. Excerpts from 2018 Water Rate Survey
- A-3. Customer Brochure

### **B. Level of Service Matrix (LOM)**

### **C. Attribute Tables and Summaries**

- C-1. Watermain Inventory Summary Tables
- C-2. Hydrant Inventory Table
- C-3. Asset Data Table (hard copy includes vertical assets only)
- C-4. Inventory Overview
- C-5. Ten-year Look Ahead
- C-6. Fifty-year Look Ahead
- C-7. One Hundred-year Look Ahead

### **D. Instruction Sheets**

### **E. System Maps**

- E-1. System Overview
- E-2. System by Pipe Diameter
- E-3. System by Pipe Material
- E-4. System by Age
- E-5. System by Impact of Failure
- E-6. System by Probability of Failure
- E-7. System by Criticality

# 1. Introduction

The Town of Newport engaged Underwood Engineers to develop an asset management program (AMP) for its water supply, storage and distribution system. The project has been funded by a \$20,000 SRF grant. The Town will contribute a \$20,000 match.

The framework of this AMP includes the following core components.

- Asset Inventory and Condition Assessment
  - What assets does the Town own?
  - Which are able to serve their purpose? Which are not?
  - What is their condition?
- Level of Service (LOS)
  - What are the Town's goals in operating and maintaining the system?
  - Goals should be specific, measurable, attainable, realistic, and timely (SMART)
- Criticality
  - Prioritize assets by their probability of failure versus their impact of failure.
- Minimum Life Cycle Cost (Practices)
  - Estimate costs needed to properly maintain, inspect, repair and, if necessary, replace assets in order to maintain the desired LOS.
- Long-Term Funding Strategy (Budget)
  - Review the current operating budget and rate structure.
  - Schedule estimated replacement costs out over the life of the assets.
  - Provide a framework for repair or replace decisions.
- Implementation and Communication Plan
  - Data
  - Planning tools
  - Management reporting
  - Public education
- Recommendations and next Steps

Note that all dollar values are in 2019 dollars. This allows for the selection and prioritization of projects. Inflation should be taken into account during the capital planning process.

## 2. Asset Inventory and Condition Assessment

Newport's water system provides service to over 1,600 customers. The main water source is Gilman Pond located in the neighboring Town of Unity. Raw water is treated at a slow sand filter plant, and is disinfected with chlorine. Sodium silicate is used to reduce taste and odor problems. The Pollards Mill Well facility was constructed in the mid-1960's to provide an additional water source. Storage facilities include a 300,000 gallon tank at the water treatment plant, and a 1.35 million gallon tank at the Summer Street facility. In addition, there is a 2.5 million gallon welded steel tank at the Summer Street facility, which was removed from service in 2000 but which has not been demolished.

Town-owned water facilities are summarized in **Table 1**.

**Table 1: Water System Summary**

Main Component	Description
<b>Vertical Assets – Sources, Treatment, Storage and Pumping</b>	
Gilman Pond	Intake facilities built in 1895. Still in service. Safe yield of 0.5 MGD.
Slow Sand Filter Water Treatment Plant	Built in 1992; 0.7 MGD capacity. Includes 0.3 MG storage tank.
Chlorination Building	Originally built in 1955. Upgraded in the late 1980's to update disinfection equipment and add corrosion control facilities. In 1993, sodium silicate facilities were added.
Pressure Reducing Valve	Built in 1934.
Pollards Mill Well Facility	Built in 1966; 0.5 MGD capacity.
Summer Street Storage Facility	Precast concrete tank built in 2000; 1.35 MG. Abandoned 2.5 MG built in 1965.
<b>Horizontal Assets - Water Distribution Pipe</b>	
Distribution piping	Over 235,600 lf of distribution main (~45 miles).
Valves	710 valves, including hydrant valves.
Hydrants	241 hydrants.

### **2.1. Condition Assessment**

For the most part, vertical assets are in serviceable condition. However, some shorter-lived assets are due for replacement or refurbishment.

Information regarding the horizontal assets, which include raw water mains, distribution mains, valves and hydrants was taken from a system study completed in 2009 by Underwood Engineers; and GIS information provided by the Town. The 2009 study included information on pipe material, diameter and approximate age. Town staff was able to provide general information on pipe break history. The cement-lined cast iron pipe installed in the mid-1960's is especially break-prone, while the older cast iron pipe installed in 1895 and 1909 has had comparatively few breaks.





Going forward, Town staff will use an online file to document incidents which can provide additional insight into pipe condition, including break records and customer complaints especially taste, odor and pressure issues.

## ***2.2. Data History, Information Sources and Organization***

Documents used to assemble the water system asset inventory include the following.


- GIS data collected by Underwood Engineers in the fall 2018 and winter of 2019.
- Comprehensive Water System Study, February 2009, Underwood Engineers.
- GIS data provided by the Town of Newport, originally assembled by CAI in 2009 and edited by Town staff over the years as needed.

The locations and lengths of water pipes were imported from the Town's water distribution system model and lined up within the road right-of-way based on field collected data. Where the two sets of field-collected data overlapped, the more recent was used.

## ***2.3. Replacement Value of Water System***

The current replacement value of the water system assets is estimated to be nearly \$82.6 million. That estimate is broken down between vertical assets and horizontal assets in **Figure 1** below. Horizontal assets constitute nearly 93% of the overall system assets with an estimated value of \$76.6 million.

**Figure 1. Overall Replacement Value**



Details regarding the age and material of water distribution pipe is provided in **Table 2**. Note that over 85,000 feet of pipe is over 100 years old. In addition, over 30,000 feet of cement lined cast iron pipe installed in the 1960's has a significant break history, even though it is only about halfway through its estimated useful life.


**Table 2. Water Distribution Pipe by Age and Material**

<b>Year Installed</b>	<b>Asbestos Cement</b>	<b>Cast Iron</b>	<b>Cement Lined Cast Iron</b>	<b>Ductile Iron</b>	<b>PVC</b>	<b>Other</b>	<b>Unknown</b>	<b>Grand Total</b>
1895		42,706		365		512	1,447	45,030
1909		40,414					323	40,736
1920		2,586						2,586
1922		1,277						1,277
1924		2,118				545		2,662
1925		1,386				790		2,175
1927		2,428						2,428
1928		1,515						1,515
1935		1,269						1,269
1950		900	732					1,633
1955	16,114	6,074						22,189
1960	6,992							6,992
1961	859					70		929
1964	522					313		835
1965	8,129						800	8,929
1966	2,698							2,698
1967	4,847		29,837	2,629				37,313
1970	644							644
1971			1,159					1,159
1975	9,599		4,518		1,148	342		15,607
1984				276				276
1985				13,913	3,475	667		18,055
1986				659				659
1994				1,384				1,384
1996				2,339				2,339
1998				879				879
2004					4,974			4,974
2005				1,782				1,782
2006					2,071			2,071
2015					415			415
2018				4,151				4,151
<b>Grand Total</b>	<b>50,404</b>	<b>102,673</b>	<b>36,246</b>	<b>28,378</b>	<b>12,083</b>	<b>3,239</b>	<b>2,570</b>	<b>235,592</b>

Replacement cost estimates are based on an all-inclusive number – meaning that engineering, design, permitting, contractor overhead, and restoration costs were all considered. Pipe replacements were assumed to include replacement of valves and hydrants as well. The unit cost of pipe replacement can vary depending of the size of the project. Typically, the larger the project, the lower the unit cost. For the purposes of this report a unit cost of \$325 per linear foot was assumed.

The replacement value of vertical assets is summarized in **Figure 2** below.

**Figure 2. Replacement Value of Vertical Assets**





### 3. Level of Service

The Level of Service (LOS) provides specific goals for the operation, maintenance, and performance of water and water structure assets. The first step in formulating the LOS is to review potential opportunities for improvement identified during the Asset Inventory and Condition Assessment process.

#### 3.1. Leaks and Water Main Breaks

The Town's water system is aging and has experienced a series of leaks and water main breaks over the years. Although over 85,000 lf of pipe is over 100 years old, breaks frequently occur in the in the cement-lined cast iron (CLCI) pipe installed in the 1960's – nearly 30,000 feet.

Watermains by remaining useful life are shown in **Table 3**.

**Table 3. Pipe by Remaining Useful Life**

<b>Remaining Useful Life</b>	<b>Total</b>
<= 0	46,525
>0 and <= 10	41,301
>10 and <= 20	22,762
>20 and <= 50	43,096
> 50	81,907
<b>Grand Total</b>	<b>235,592</b>

Altogether, approximately 87,000 lf of pipe will soon exceed its remaining useful life and 30,000 lf has a significant history of breaks.

#### 3.2. Data and Follow-up

As the Town's infrastructure ages, maintenance and upkeep continues to consume more staff time. An automated, streamlined system of data and follow-up would enable easier access to information for decision-making. The Town uses CAI's AxisGIS system, which allows staff to make edits to the Town's GIS files. In addition to the inventory files, an empty file will also be provided which staff can use to record leaks, breaks and other incidents.

This information should be updated on a regular basis and shared with the Board of Selectmen and the public so that they are aware of ongoing performance issues with the system.

#### 3.3. Financial Resources

In order to keep up with necessary asset renewals going forward, significant financial resources will be required. Over \$30 million worth of assets, primarily watermains, will be due for replacement in the next ten years. The Town will need to build sufficient resources for asset renewals into its financial plan. Ultimately, the goal should be to work through the existing back log and incorporate asset renewals into the water utility's financial plan going forward in order to avoid a back log in the future.

As projects are evaluated during the capital improvement planning process, cost-saving measures may become apparent. These may include the following:

- Eliminate redundant watermain. There are several areas where multiple watermain run parallel to one another.
- Install cross-over lines on the Unity Road transmission main.
- Combining water main projects with other projects, such as roadway improvement projects or sewer projects.
- Using cost-reducing installation technologies, such as pipe-bursting, which is approximately two-thirds the cost of full replacement.

A Level of Service Matrix is provided in **Appendix B**, which addresses the Town's goals going forward.



## 4. Critical Assets and Priority Projects

In order to allocate scarce financial and physical resources in the most efficient possible way, it is necessary to systematically prioritize projects. For the purposes of this AMP, assets will be ranked by their criticality. Criticality is defined as probability of failure versus impact of failure.

A condition assessment was not performed for the water pipes or water structures. Probability of failure was surmised based on remaining useful life, which was surmised based on estimated age and material.

1. Very Low Risk-Asset is extremely reliable
2. Low Risk-Sporadic Failures possible
3. Moderate Risk-Possibility of Failure
4. High Risk-Asset sometimes fails to meet performance requirements.
5. Very High Risk-Asset is likely to fail or has failed to meet performance requirements.

An impact of failure score was assigned to each component based on the severity of consequences in the event of a break or malfunction. Factors such the effect on public health, potential number of customers impacted, lack of redundancy, and cost of repair were taken into account.


1. Very Low Impact- Public health and safety is very unlikely to be affected in the event of a failure. A small number of single-family residential customers would be inconvenienced. Repair cost is minimal.
2. Low Impact-Public health and safety are unlikely to be affected. A small number of single-family residential or small commercial customers would be inconvenienced. Repair cost is low.
3. Moderate Impact- Public health and safety are moderately likely to be affected. A large number of customers would be inconvenienced, or the impact on the customers affected would be serious. Repair cost is moderate to high.
4. High Impact-Moderate to high potential for public health and safety to be affected. A large number of customers would be inconvenienced, or the impact on the customers affected would be serious. Repair cost is high
5. Very High Impact- High potential for public health and public safety to be affected. A large number of customers would be inconvenienced, or the impact on the customers affected would be serious. Repair cost is very high

These factors taken together with the condition of the asset form the basis for the criticality of the asset. If an asset is in poor condition (has a high probability of failure), but is unlikely to have a significant impact in the event of a failure then it would be lower on the priority list than an asset in poor condition which would have a major impact in the event of a failure. The impact of failure versus the probability of failure can be summarized as follows:

- Highest Risk – high probability of failure and high impact of failure.
- Priority Renewal – high probability of failure and low impact of failure.
- Frequent Monitoring – low probability of failure and high impact of failure.
- Limited Monitoring – low probability of failure and low impact of failure.

See **Figure 3** for a visual representation of criticality scoring.

**Figure 3. Criticality Matrix**



Water mains are mapped by probability of failure (ie. condition), impact of failure and criticality in **Appendix E**.

It should be noted that the criticality of the Unity Road transmission mains, the WTP, and Pollards Mill Well are reduced if a new groundwater supply is established in an area that is not directly linked to Unity Road. Additionally, the criticality of the Unity Road transmission mains are reduced if cross-over lines are installed along the road at strategic locations.

## 5. Minimum Life Cycle Cost (Practices)

The Town completed a rate study update in June 2018. At that time, it was determined that working capital balances would become negative in the 2020-21, and a rate increase of 60% would be required to bring working capital balances to the lower end of the recommended range.

It should be noted that rates are a factor in qualifying for State Revolving Fund (SRF) loans. According to the “2018 Drinking Water State Revolving Fund Intended Use Plan”, points are awarded as shown in **Table 4**. The 2018 New Hampshire Water and Wastewater Rates Dashboard indicates that the annual water bill for a typical household in Newport is \$513.36 per year, and median household income is \$58,193 per year. Since that survey was completed, the Town has raised rates by 10%, increasing the annual water bill to approximately \$565.00 per year. This would result in an affordability ratio of approximately 0.97. Since Newport’s MHI is lower than state-wide MHI, the Town may also qualify for subsidies.

The Water and Wastewater Rates Dashboard can be found at this link:

<https://efc.sog.unc.edu/resource/new-hampshire-2018-water-and-wastewater-rates-dashboard>

The Intended Use Plan can be found here:

<https://www.des.nh.gov/organization/commissioner/pip/publications/documents/r-wd-18-12.pdf>

**Table 4. Impact of Affordability on SRF Loan Application Evaluation**

<b>Affordability Ratio (Water Rate/MHI)</b>	<b>Priority Points</b>
2.00 or more	15
1.6 to 1.99	11
0.8 to 1.5	7

Total water system replacement costs have been scheduled out each year for the next ten years in **Table 5**. The estimates for water main replacements are based on full replacement costs, and include such items as engineering, design and restoration. The scheduled replacement date is based on the estimated year of installation, and remaining useful life as discussed in Section 3. According to available data the estimated cost of needed replacements over the next ten years is approximately \$31.0 million based on age and condition alone.

**Table 5. Estimated Replacement Costs - Ten Years**

<b>Water System Component</b>	<b>2019-2028</b>
Water Distribution System	\$28,543,467
Water Meters	\$990,000
Pollards Mill Well Facility	\$604,000
Slow Sand Filter Water Treatment Plant	\$503,000
Vehicles/Equipment	\$142,000
PRV Building	\$85,000
Gilman Pond Water Supply	\$50,000
Sodium Silicate Building	\$38,000
<b>Grand Total</b>	<b>\$30,955,467</b>



The most urgent projects can be determined by ranking projects by Criticality and Risk Score (Impact of Failure x Probability of Failure). See a summary in **Table 6** below. Additional details are provided in **Appendix C**.

**Table 6. Estimated Replacement Costs by Risk Score – Ten Years**

<b>Risk Score</b>	<b>Estimated Cost</b>
25.0	\$7,194,274
20.0	\$9,859,956
16.0	\$4,465,794
15.0	\$4,142,969
12.0	\$2,140,188
10.0	\$2,026,748
5.0	\$690,204
4.0	\$435,334
<b>Grand Total</b>	<b>\$30,955,467</b>

This table includes approximately \$13.5 million worth of transmission and distribution mains which run parallel to other pipes. If the redundant piping is abandoned the total financial need could be substantially reduced. However, there are costs associated with abandoning these mains (ex. transferring services or making new interconnections) which would reduce the cost savings. These costs are difficult to estimate accurately without additional information. Twenty percent (20%) is a reasonable starting assumption. Once this work is complete, renewals or replacements could be segmented out over a number of years in order to maintain a financially manageable capital improvements program. Since the transmission mains south of the golf course have relatively few tie-ins, it may be possible to use cost-reducing installation technologies, such as pipe bursting.

While there is a large immediate need, that need tails off after the first decade if adequate funds are allocated. The Town could fund early projects with SRF loans and build up reserves for future needs over time.


**Table 7. Estimated Asset Renewals per Year for the Next 50 Years**

<b>Decade</b>	<b>Estimated Cost</b>
2019-2028	\$30,955,467
2029-2038	\$8,216,384
2039-2048	\$9,614,985
2049-2058	\$5,977,480
2059-2068	\$4,076,111
<b>2019-2068</b>	<b>\$58,840,427</b>

A rate study completed by the Town in 2018 indicates that until the recent 10% rate increase, water revenues have been trending downwards. See **Figure 4**. At the same time, the need for asset renewals has sharply increased as assets reach the end of their estimated useful lives or have experienced performance issues.

Approximately 45,000 feet of cast iron pipe installed in 1895 reached the end of its estimated useful life in 2010. Nearly 41,000 feet of cast iron pipe installed in 1909 will reach the end of its estimated useful life in 2024. In addition, approximately 30,000 feet of cement-lined cast iron pipe installed in the 1960's has a significant break history.

**Figure 4. Water Billed (gpd) and Revenue from User Fees (2018 Rate Study)**





## 6. Long Term Funding Plan (Budget)

The one-hundred-year replacement schedule in **Table 8** and **Figure 5** includes shorter-lived assets that will need to be replaced multiple times. For that reason, replacement costs over a 100-year time span would be somewhat greater than the replacement value of the assets as shown in **Figure 2**.

The 100-year replacement schedule reveals that water system asset renewal will be an ongoing need for the Town. One way for the Town to keep up with renewals is to borrow to fund asset renewal projects needed today; and then increase capital reserves over time.

It should be noted that **these costs are provided in 2019 dollars** to allow for the comparison and prioritization of projects. Inflation should be factored in for the purposes of future financial planning. As mentioned above, detailed information regarding pipe condition and performance should be collected. This would allow the Town to plan renewals based on the overall functionality of the asset rather than just its age.

The Town will need to find a way to spread out the cost of addressing the \$31 million backlog over a longer time period, while at the same time ensuring that future asset renewals are addressed in a timely manner. One possible scenario is outlined in **Table 8**. The suggested strategy is to combine the anticipated need for the first thirty years (approximately \$48 million) and spread it out over that time period. After that, the need is reduced. The first thirty years will almost certainly require loan financing. After that, sufficient reserves can be set aside to address recurring needs.


**Table 8. Estimated Replacement Costs – Next 100 Years**

<b>Decade</b>	<b>Estimated Cost</b>	<b>Financial Forecast</b>	<b>\$ per Year</b>
2019-2028	\$30,955,467	\$16,300,000	\$1,630,000
2029-2038	\$8,216,384	\$16,300,000	\$1,630,000
2039-2048	\$9,614,985	\$16,300,000	\$1,630,000
2049-2058	\$5,977,480	\$9,100,000	\$910,000
2059-2068	\$4,076,111	\$9,100,000	\$910,000
2069-2078	\$5,336,483	\$9,100,000	\$910,000
2079-2088	\$15,877,271	\$9,100,000	\$910,000
2089-2098	\$9,192,843	\$9,100,000	\$910,000
2099-2108	\$2,023,526	\$9,100,000	\$910,000
2109-2118	\$7,699,429	\$9,100,000	\$910,000
<b>2019-2118</b>	<b>\$98,969,979</b>	<b>\$112,600,000</b>	

By examining rates and completing an asset management plan, the Town has taken the first steps in preparing financially to address its aging water system, especially the pipe network. As mentioned earlier, it is possible to reduce the financial need by implementing cost-saving measures; and to reduce the criticality of the Unity Road transmission mains by developing a water supply which is independent of those facilities. In addition, it may be possible to receive a certain amount of SRF loan forgiveness.



**Figure 5. Estimated Replacement Costs – Next 100 Years**



Additional steps would include documenting pipe breaks and repairs, including the following information:


1. Location, length and material of pipe.
2. Failure mechanism, if it can be determined. Was it deterioration on the outside of the pipe? Deterioration on the inside of the pipe? An installation issue, such as improper bedding?
3. Total cost of the repair, including materials, overtime, cost of contractor, property damage, etc.
4. Number of man hours spent on the repair.
5. How many customers were affected and for how long? Was there a service interruption? Was there damage to private property, the roadway, or other facilities?
6. How much water was lost as a result of the break?

Collecting detailed information regarding pipe breaks and repairs would help the Town compute the total actual costs and make better predictions as to when assets should be renewed.

## 7. Implementation and Communication Plan

As discussed in Section 2, the Town's aging water system requires a comprehensive data collection effort to better schedule out replacements based on break and repair history. A schematic overview of the proposed plan is provided in **Figure 6** below.

**Figure 6. Implementation Flow Chart**



The Town's horizontal water system assets (pipes, valves and hydrants) have been mapped in ArcGIS. The GIS files include information on the age, material, condition and criticality of each component. This information will be stored and can be updated in AxisGIS and exported to Excel for further processing and evaluation. Vertical assets are items such as well facilities, which include numerous sub-components. Information associated with these assets has been assembled into a spreadsheet. Information from the all of the assets combined can be summarized in pivot tables within the spreadsheet in order to provide a comprehensive financial overview of the entire system.


The files assembled to date are a snap shot in time. They will be need to be updated as additional information about the system is gathered; and repairs, replacements and upgrades are made. The Town has been using AxisGIS and will continue to use that as the primary information gathering and storage medium.

The information assembled can be used as the basis for a staffing plan, operating budget and capital budget. It can also be used to generate reports, which can be used to educate and inform the Select Board and the public. A communication flow chart is provided in **Figure 7**.

One goal of the communication plan should be to detail the consequences of water main breaks and associated emergency repairs. The Board of Selectmen members and the public should be made aware of the full impact of such an event – not only in terms of the immediate cost of the repair, but of additional man hours and overtime, cost of damage to other facilities, cost of lost water, the number of customers affected and the length of the service disruption.

The Town's main method of communicating to customers is the annual report, which lists the number of breaks and repairs in addition to other activities. However, the public should also know the full of those repairs.

**Figure 7. Communication Flow Chart**



## 8. Conclusions and Recommendations

The total replacement cost of the Town's water system assets is estimated to be nearly \$82.6 million as shown in **Figure 1**, which can be found in Section 2.3 of this report. At present, the Town does not have comprehensive condition information on the system. Therefore, condition assessment is based primarily on age. However, Town staff has observed that the cement-lined cast iron pipe installed in the 1960's appears to be more break-prone than other pipe in the system.

To keep up with immediate asset renewal needs, the Town will most likely need to borrow and build capital reserves simultaneously. The Town is currently in "catch-up mode" with a \$31 million backlog of asset renewals. In order to address the backlog, the Town will need to increase rates significantly and borrow in the early decades. Once the backlog tails off, it is recommended that the Town begin to address asset renewals on a regular basis. One possible scenario is outlined in **Table 8**. Under this scenario, approximately \$1.63 million (in 2019 dollars) would be set aside each year for thirty so that the Town can work through the initial backlog. After that, approximately \$910,000 (in 2019 dollars) would be set aside each year to ensure that adequate resources are available to address asset renewals as the need arises. This will enable the Town to avoid sudden, large rate increases in the future in order to cover unaddressed capital needs.

Rate affordability should be evaluated to optimize potential loan forgiveness from NHDES. Since the long-term solution is neither straight-forward nor inexpensive, a detailed evaluation and capital improvement plan needs to be completed. It is understood that the wastewater collection and stormwater systems are in similar condition. Therefore, all these systems as well as road improvements will need to be mapped out in order to prioritize projects and identify overlapping needs.

It is recommended that the Town institute a comprehensive record-keeping program to collect detailed information on water main breaks. The ultimate goal is that the Town will be better able to identify which pipes should be scheduled for repair or replacement.

The Town already has a paper-based data system. Unfortunately, it is difficult to compile and share the information collected. The Town also needs to track certain items more closely, such as the true cost of emergency repairs. To start, an empty shapefile has been provided, which will allow staff to quickly and easily collect, summarize and transmit data. As the Town moves forward with its asset management program and staff becomes more comfortable, additional data collection mechanisms can be developed.

## **APPENDIX A**

### **Financial Information**



detailed work plan for the 10%, 2% and 15% setasides. In general, the 10% setaside supports monitoring, enforcement, laboratory certification, private well initiative, operator certification, engineering and plan review, as well as information management activities. Funding from this setaside (\$140,000), along with the 15% setaside, will be used to promote asset management to improve compliance at NH's public water systems. Attachment B contains the budget that details how this and the 2% and 15% setasides will be used.

#### **4B (4). 15% Source Water Protection and Capacity Development**

A number of activities will be funded from the FFY18 15% setaside (\$1,666,050) and the estimated prior year funds (\$926,451), including capacity development and source water protection. Source water protection activities will include technical and financial (grants and contracts) assistance and performance of regulatory functions related to new well sitings. Other capacity development activities beyond source protection will also occur. It will also include tracking the progress of New Hampshire's current Capacity Development Program and the ongoing provision of technical assistance to improve small systems managerial, financial and technical capabilities. The state also plans to continue funding a highly successful leak detection contractor (\$70,000 provided by this setaside and \$50,000 provided by the 2% setaside) to work with systems committed to finding and fixing leaks as well as grants for asset management plans (\$160,000 with an additional \$140,000 provided through the 10% setaside). Solicitation for Local Source Water Protection Grant Program (\$200,000) is open until November 1, 2017. Grant applications for all grants funded by the DWSRF are available on the NHDES website. Hard copies of these and contractual agreements funded by the setasides will be provided to EPA.

#### **4C. Transferring Funds from Setasides into Infrastructure Project Account**

NHDES reserves the right to transfer monies from setaside accounts into the infrastructure project account should the need arise.

### **5. PRIORITIZATION OF GRANTS AND FINANCIAL ASSISTANCE**

The criteria for prioritizing source water protection and asset management grant applications are contained in the request for grant proposals to be provided to EPA. The assistance to help small community water systems develop record drawings will continue to be done on a first-in, first out basis. Use of a leak detection contractor will continue to occur on a first come, first served, readiness basis.

### **6. CRITERIA AND METHOD FOR DISTRIBUTION OF INFRASTRUCTURE PROJECT FUNDS**

In FFY2018 the state must provide a minimum of 20% of the capitalization grant to subsidize infrastructure projects for disadvantaged systems but may provide up to 30%. To meet this goal, New Hampshire will fund projects in disadvantaged communities on a priority basis.

## 6A. Description of Process for Selection of Eligible Systems to Receive Assistance

The state of New Hampshire utilizes a ranking system to prioritize the order in which eligible projects will be financed. Projects are ranked based upon the relative impact of the project in achieving the objectives of the Safe Drinking Water Act and, in 2018, priority will continue to be given to projects in disadvantaged communities. In general, highest priority will be given to projects in disadvantaged communities that facilitate compliance with national primary drinking water regulations applicable to the system under title 1412 or otherwise significantly further the health protection objectives of this title (1452(a)(2)). Projects in need of improved capacity will also be given priority. Although, there is not a requirement to fund “green” projects. NHDES intends to award priority points for certain types of green projects identified in a system’s energy or water use efficiency or sustainability plan.

Prior to funding any project, every effort is made to evaluate an applicant’s financial, technical and managerial capacity prior to issuing a loan. This is accomplished by reviewing plans, designs, documents and compliance records, as well as completion of a capacity self-assessment form as a condition of the loan application. Loans will not be issued to those applicants lacking the necessary capacity to effectively own, operate and maintain their system(s). The priority ranking system that was used to produce the list in Section 9 is explained in the following subsections.

### 6A (1). Priority Ranking Formula

**Project priority points (P) will be derived using the following formula:**

$$P = (A+B+C+D+E+F+G+H+I+J)$$

Where:

- A** = Existing violations of drinking water standards
- B** = Existing deficiencies in the supply or storage of drinking water
- C** = Existing deficiencies in treatment or design
- D** = NHDES capacity development need
- E** = System interconnection
- F** = Affordability (ratio of annual water rate vs. median household income)
- G** = Implements “green” recommendations from energy or water use efficiency or sustainability plan.
- H** = Addresses critical infrastructure needs
- I** = Asset Management (AM) program in place and project identified in an AM plan
- J** = Lead component/service line replacement project

Eligible applicants for project funding include municipal or privately owned community water systems and non-profit organizations that operate public water systems that are non-community but serve a non-transient population such as: schools, hospitals and large work places. Seasonal or communities with less than 50% of households whose residents are permanent are not eligible for Category F and will not receive subsidization.

## **Description of Factors**

Factors used in the formula are described and weighted below. Factors and points apply to the system applying for assistance. For projects where an interconnection is proposed, points can be awarded for the relief of problems in the satellite system(s).

<b>A = Violations of National Drinking Water Standards</b>		
Maximum Contaminant Levels (MCL) are established by the federal or state Safe Drinking Water Act (SDWA) for those contaminants which may be detrimental to public health. Exceedances of these levels in the last year (the last three years for secondary contaminants) at community public water systems, of contaminants that will be addressed by the project, carry the following weightings. Points are given for all of the following that apply to a system and will be addressed by the project:		
<b>Condition</b>		<b>Priority Points</b>
a. Total and fecal coliforms		
	1. No detections	0
	2. 1-2 TCR assessments	30
	3. Greater than 2 assessments	40
	4. Boil order	60
b. Nitrate or emerging contaminant with do-not-drink health advisory/AGQS		
	1. No level above 1.0 mg/L (N) or HA/AGQS	0
	2. Levels >5.0<10mg/L (N)	26
	3. MCL violations (N) or HA exceedence/AGQS	60
c. Filtration or Disinfection related Treatment Techniques		
	1. No violations	0
	2. 1-2 treatment technique violations	26
	3. Greater than 2 violations	52
d. Chemical or Disinfection Byproducts MCL violations		
	1. No MCL violations	0
	2. 1-2 MCL violations	26
	3. Greater than 2 violations	52
e. Lead and Copper (At the 90th percentile)		
	1. Lead levels above .015 mg/l	52
	2. Copper levels above 3.0 mg/l	24
	3. Copper levels between 1.3 and 3.0 mg/l	18
f. Secondary Standards		
	Any exceedance of a secondary MCL	14

<b>B = Quantity Deficiencies or Insufficient Storage</b>	
Quantity deficiencies are shortages due to limited water supply sources or insufficient storage within the distribution system to meet public need. The public health and compliance risks associated with quantity deficiencies include domestic need of adequate potable water for drinking and hygiene, and maintaining adequate pressure in lines to prevent back siphonage and cross-connections. The following priority points may be assigned only for current or recent (within last five years) unaddressed shortages. Projects related to future growth or expansions are not eligible for funding.	
<b>Condition</b>	<b>Priority Points</b>
Adequate quantity for the present (meets all current demand)	0
Continual shortage (daily)	22
Shortage of supply recognized by NHDES	20
Insufficient storage capacity/storage tank	20
Shortage during peak demands	20
Shortage during seasonal high use in a system with an implemented conservation plan	18
Shortage during seasonal high use in a system without an implemented conservation plan	14

<b>C = Treatment/Design Deficiencies</b>	
Design deficiencies are those which could be corrected by enlargement, repair, installation, or replacement of all or a portion of the system. Any combination of the following deficiencies has the potential to adversely affect a system's ability to continually provide drinking water that meets all standards.	
<b>Condition</b>	<b>Priority Points</b>
Incomplete surface water filtration or presence of groundwater under the influence of surface water	22
Confined space pumphouse/other safety issues	18
Non-optimized surface water filtration when compared with American Water Works Association composite correction criteria	18
Mandated chlorination of groundwater system	14
Distribution/plant capacity deficiencies (includes situations where current demand exceeds treatment capacity; pipe tuberculation; pressure issues; asbestos cement removal, high unaccounted for water)	18
Need to upgrade existing corrosion control treatment in order to meet action levels	17
Improper well construction	16
Inadequate water treatment wastewater disposal (backwash or sludge)	14
Other significant deficiencies (e.g. need for treatment of Arsenic, Iron, Manganese, Radon, Radionuclides; other deficiencies observed during a sanitary survey)	14
Backup power source	5

**D = Capacity Development**

Public water systems in need of significant technical, managerial or financial assistance through the capacity development program are identified through a variety of mechanisms including sanitary surveys, referrals from contract operators, direct requests from the water system, customer complaints, and repeat enforcement and significant non-complier lists. Systems are notified of the recommended improvements in their sanitary survey report or technical assistance site visit reports and are entered into our capacity development tracking database. Systems on the capacity development list are typically very small systems serving less than 100 homes.

Public water systems with capacity needs serving 1,000 people or less	20
---	----

**E = Consolidation**

The project involves interconnection to a more viable public water system.	20
--	----

**F = Affordability**

Affordability is an indicator of a rate payer's ability to afford rate increases that will result from a project. Affordability is determined by a ratio that compares the average water rate to the median household income of the community that is applying for funding. Below is a table which provides points based on this ratio. Only year round communities that are considered disadvantaged will be eligible for these points. The water rates are based on the most recent information compiled by NHDES in its 2018 water rate survey report or from information provided directly by the applicant. The median household income (MHI) is the income data compiled by the U.S. Census Bureau 2012-2016 American Community Survey. The affordability ratio is calculated by dividing the water rate by the community median household income times 100%.

Affordability Ratio (Water Rate/MHI)	Priority Points
2.00 or more	15
1.6 to 1.99	11
0.8 to 1.5	7

**G = "Green"**

Projects that include energy or water efficiency improvements will be assigned points. In general, green projects include, but are not limited to, energy generation, leak repair, meter installations or upgrades, pump efficiency, water infiltration/storage projects, high efficiency pumps and motors, variable frequency drives, water main replacement or any other activities identified in a conservation plan.	15
--	----

**H = Critical Infrastructure**

If the project upgrades, replaces or supplements critical infrastructure components such as sole sources of supply, storage tanks, transmission mains, river crossings, or other such infrastructure the failure of which could interrupt water service to the entire water system, or a significant portion thereof, then the project will be assigned ranking points.	15
---	----

<b>I = Asset Management</b>	
If the system has completed activities related to an active asset management program then the project will be assigned ranking points.	
<b>Condition</b>	<b>Priority Points</b>
Project is directly from the systems asset management plan	10
The system has implemented a complete asset management plan	5
The system has implemented some components of an asset management plan	2
The system has not completed any asset management implementation	0

<b>J = Lead</b>	
Any lead component or lead service line (all the way to the meter) replacement project	50

### **6A (2). Tie-Breaking Procedure**

When two or more projects score equally under the Project Ranking Formula, tie-breaking procedures will be utilized. The first tie-breaking procedure is related to long-term financing of the projects. A project that intends to use the DWSRF for long-term financing will receive the higher ranking. If both projects are to use the DWSRF for long-term financing, in order to direct financial resources where they will benefit the greatest number of people, and because the vast majority of New Hampshire's systems are either small or very small, (statewide, only 18 systems serve greater than 10,000 people) the project with the greater existing population served will receive the higher ranking.

### **6A (3). Bypass Procedure**

Because of the need to apply quickly for available federal dollars and the unpredictability of when funds become available, projects that score high but cannot obtain authority to borrow before June 2019, may be temporarily by-passed. Also, a project on the fundable portion of the main list may be bypassed if it is determined that the project will not be ready to proceed for other reasons during the funding year or, if the cost of the project will prevent the state from meeting the grant conditions requiring that 15% of the grant be used to fund projects in small systems, and that 20% be used to subsidize loans to disadvantaged communities. Any applicant whose project is to be bypassed will be given written notice by NHDES. It is the department's intent to work with these systems to assist them in getting ready to proceed. Funds which become available due to the utilization of the bypass procedure will be treated in the same way as additional allotments.

### **6A (4). Emergency Projects**

Projects necessary to alleviate emergency situations that result in an imminent threat to public health, such as: the total loss of water supply or loss of a major component due to a natural or unforeseen disaster which could not have been prevented by the applicant (e.g. tornado, flood, severe weather, fire, collapse, emerging contaminant that is acute in nature for some

population, etc.), or other water emergencies which could not have been prevented by exercise of reasonable care by the applicant, can be immediately elevated to the top of the priority list at the discretion of the department.

#### **6A (5). Refinancing Existing Loans**

The DWSRF may be used to buy or refinance debt obligations for DWSRF eligible projects not currently financed through the DWSRF. Debt obligations for private systems are not eligible for refinancing under the DWSRF. The long-term debt must have been incurred after July 1, 1993, to be eligible for refinancing. DWSRF monies cannot be used to refinance loans for the purchase of land. Priority for refinancing will go to systems having the highest user rate. Consideration for these applications will be entertained only after projects addressing public health protection and compliance have been funded. If funded, the refinanced project must have complied with all federal and state requirements for the DWSRF program including applicable Davis-Bacon Act and the American Iron and Steel provision requirements.

#### **6B. Impact of Funding Decisions on the Long Term Financial Health of the DWSRF**

The rate structure for loans will encourage short-term loans; thereby freeing up funds for more loans. Financial modeling indicates that even with the measures being put into place to address disadvantaged communities; reduce ULOs, the integrity of the fund will be maintained and growth will occur.

#### **6C. Relationship to State Program Goals and Objectives**

NHDES places priority on categories of projects that meet departmental goals as stated in the long- and short-term goals of the IUP (Section 2). In general, the resolution of imminent threat to public health by addressing acute contaminants at disadvantaged communities is paramount, followed by the resolution of such issues elsewhere. Other compliance issues, improved capacity and promotion of “green” projects are also goals supported by New Hampshire’s prioritization approach.

### **7. ASSISTANCE TO SMALL SYSTEMS**

A minimum of 15% of the total amount available for assistance from the fund must be made available to provide infrastructure loan assistance to systems serving fewer than 10,000 people. Accordingly, New Hampshire intends to dedicate at least \$1,666,050 for loans to eligible small systems for eligible infrastructure projects.

### **8. DISADVANTAGED COMMUNITY/SYSTEM PROGRAM**

New Hampshire will provide at least 20%, not to exceed 30%, of available funding in the form of loan subsidies to disadvantaged communities. The percentage of principal forgiveness will be adjusted as needed, as provided in 8D below, to ensure that this goal is met and, if necessary, bypass provisions will be utilized.



## **8A. Definition**

A disadvantaged community or system is defined as a community public water system or community that serves residents whose median household income (MHI) is less than the statewide MHI (Attachment E) based on the most recent census data and/or income survey. If an applicant for DWSRF assistance meets the definition of “disadvantaged” and if the resulting project user rate (which is the total of the existing rate in addition to the rate that results from the new project) exceeds the statewide affordability criteria (see 8C), it may be eligible for subsidies from the Disadvantaged Community/System Program. Subsidies will be available in the form of principal forgiveness. This program only applies to infrastructure projects.

## **8B. Limitations to Disadvantaged Program Assistance**

To qualify for disadvantaged program assistance, at least 50% of the residential units served by the water system must be occupied at least six months of the year by a population meeting the disadvantaged income criterion (i.e. Project MHI < Statewide MHI). A project requesting interim financing will also not be eligible for disadvantaged system assistance.

## **8C. Affordability Criteria and Terms of Financial Assistance**

Affordability of a proposed project considers both the resulting user rate (based on usage of 71,996 gallons per household per year) and the MHI of the community system or community in which the system exists. An affordable project is one that results in user rates that do not exceed 0.8% of the system or town MHI. For the purpose of determining the level of subsidy given the applicant through the Disadvantaged Community/System Program, the following process is followed:

Communities or systems requesting a loan that have an MHI less than the statewide MHI (based on the most recent census data and/or income survey), which for New Hampshire is \$68,485 using the 2012 - 2016 American Community Survey data, are identified and considered disadvantaged. Provided they score enough points to be funded using the previously described prioritization ranking methodology, they will be given a subsidy in the form of principal forgiveness to bring the resulting user rate closer to being considered “affordable.” The level of subsidy is determined by using an Affordability Index, which serves to measure the impact of a project on a disadvantaged community. The index is calculated by dividing the project user rate by the community or community system’s MHI. Loans, rates and terms for this program will be the same as those for standard project loans.

### Disadvantaged System Assistance

Affordability Index* (project user rate / community or water system's MHI)	Minimum Principal Forgiveness
0.8 to < 1.50	10%
1.50 to < 2.00	15%
≥ 2.00	20%

\*See Attachment E for community MHI figures used in the calculations.

Community systems that are county owned are eligible for forgiveness as long as the county MHI is below the statewide MHI. The level of subsidy will be determined based on the chart below.

### County Owned Community Systems Disadvantaged System Assistance

Median Household Income (MHI)	Amount of Principal Forgiveness
\$68,485-\$50,000	10%
Below \$50,000	15%

## 8D. Amount of Funding to be Provided to Disadvantaged Communities/Systems

NHDES intends to reserve 20% of the DWSRF capitalization grant to subsidize eligible projects at community water systems in disadvantaged communities. Subsidy will be provided in the form of principal forgiveness. To meet this goal, the amount of subsidy for a project will be determined at the time of the loan agreement in accordance with the table above. The New Hampshire DWSRF program reserves the right to increase the principal forgiveness percentages in the Disadvantaged System Assistance table in section 8C, above, in order to meet the 20% disadvantaged subsidy goal. If necessary, each category of principal forgiveness in the tables above will be increased by an equal amount to ensure that the total amount of loan forgiveness under the 2018 PPL meets the amount required by the federal grant (i.e., 20% of the capitalization grant amount).

## 8E. Identification of Systems to Receive Assistance

Projects have been prioritized using the system described in section 6A and identified on the project priority list as eligible for assistance from the Disadvantaged Community/System Program.

## 8F. Long Term Effect of Subsidies on the DWSRF

The anticipated net long-term effect of the allocation of funds for financial assistance to Disadvantaged Communities/Systems, as proposed, will be to reduce the amount of funds available to the standard project fund in the amount of \$2,221,400.

# EXHIBIT 4

## WATER AND SEWER USAGE AS BILLED ANNUAL SUMMARY 1997-2017

		WATER					SEWER				
		TOTAL	GENERAL	%	RUGER	%	TOTAL	GENERAL	%	RUGER	%
1997	1	45,832	34,563	75.4%	11,269	24.6%	36,701	28,999	79.0%	7,702	21.0%
1997	2	52,993	38,234	72.1%	14,759	27.9%	39,629	29,961	75.6%	9,668	24.4%
1997	3	54,612	40,208	73.6%	14,404	26.4%	41,608	32,463	78.0%	9,145	22.0%
1997	TOTAL	153,437	113,005	73.6%	40,432	26.4%	117,938	91,423	77.5%	26,515	22.5%
1998	1	45,058	32,290	71.7%	12,768	28.3%	36,378	26,610	73.1%	9,768	26.9%
1998	2	63,743	45,247	71.0%	18,496	29.0%	48,833	35,868	73.5%	12,965	26.5%
1998	3	46,574	35,143	75.5%	11,431	24.5%	33,585	26,064	77.6%	7,521	22.4%
1998	TOTAL	155,375	112,680	72.5%	42,695	27.5%	118,796	88,542	74.5%	30,254	25.5%
1999	1	50,019	37,519	75.0%	12,500	25.0%	38,525	29,454	76.5%	9,071	23.5%
1999	2	55,437	42,543	76.7%	12,894	23.3%	41,460	32,347	78.0%	9,113	22.0%
1999	3	47,184	33,402	70.8%	13,782	29.2%	36,292	26,268	72.4%	10,024	27.6%
1999	TOTAL	152,640	113,464	74.3%	39,176	25.7%	116,277	88,069	75.7%	28,208	24.3%
2000	1	57,681	42,356	73.4%	15,325	26.6%	44,335	32,579	73.5%	11,756	26.5%
2000	2	60,664	45,733	75.4%	14,931	24.6%	45,782	35,132	76.7%	10,650	23.3%
2000	3	38,116	28,069	73.6%	10,047	26.4%	29,583	22,433	75.8%	7,150	24.2%
2000	TOTAL	156,461	116,158	74.2%	40,303	25.8%	119,700	90,144	75.3%	29,556	24.7%
2001	1	47,321	35,585	75.2%	11,736	24.8%	38,873	30,028	77.2%	8,845	22.8%
2001	2	36,710	28,756	78.3%	7,954	21.7%	29,058	22,567	77.7%	6,491	22.3%
2001	3	51,422	40,689	79.1%	10,733	20.9%	41,043	31,927	77.8%	9,116	22.2%
2001	TOTAL	135,453	105,030	77.5%	30,423	22.5%	108,974	84,522	77.6%	24,452	22.4%
2002	1	39,389	30,253	76.8%	9,136	23.2%	32,296	24,885	77.1%	7,411	22.9%
2002	2	51,549	40,554	78.7%	10,995	21.3%	40,048	30,735	76.7%	9,313	23.3%
2002	3	44,087	33,793	76.7%	10,294	23.3%	34,319	25,887	75.4%	8,432	24.6%
2002	TOTAL	135,025	104,600	77.5%	30,425	22.5%	106,663	81,507	76.4%	25,156	23.6%
2003	1	39,835	32,596	81.8%	7,239	18.2%	32,650	26,717	81.8%	5,933	18.2%
2003	2	46,346	37,460	80.8%	8,887	19.2%	39,015	30,126	77.2%	8,887	22.8%
2003	3	44,424	34,778	78.3%	9,646	21.7%	35,786	26,140	73.0%	9,646	27.0%
2003	TOTAL	130,605	104,834	80.3%	25,772	19.7%	107,451	82,983	77.2%	24,466	22.8%
2004	1	39,063	32,178	82.4%	6,885	17.6%	33,386	26,501	79.4%	6,885	20.6%
2004	2	50,688	40,037	79.0%	10,651	21.0%	40,749	30,098	73.9%	10,651	26.1%
2004	3	43,555	35,618	81.8%	7,937	18.2%	36,317	28,380	78.1%	7,937	21.9%
2004	TOTAL	133,306	107,833	80.9%	25,473	19.1%	110,452	84,979	76.9%	25,473	23.1%
2005	1	40,079	29,953	74.7%	7,709	19.2%	34,657	26,948	77.8%	7,709	22.2%
2005	2	42,178	32,115	76.1%	7,647	18.1%	35,171	27,524	78.3%	7,647	21.7%
2005	3	40,765	30,315	74.4%	8,034	19.7%	34,922	26,888	77.0%	8,034	23.0%
2005	TOTAL	123,022	92,383	75.1%	23,390	19.0%	104,750	81,360	77.7%	23,390	22.3%
2006	1	39,620	29,264	73.9%	7,940	20.0%	34,657	26,717	77.1%	7,940	22.9%
2006	2	42,820	33,536	78.3%	6,807	15.9%	35,171	28,364	80.6%	6,807	19.4%
2006	3	41,277	31,111	75.4%	7,758	18.8%	34,922	27,164	77.8%	7,758	22.2%
2006	TOTAL	123,717	93,911	75.9%	22,505	18.2%	104,750	82,245	78.5%	22,505	21.5%
2007	1	37,762	29,085	77.0%	6,269	16.6%	32,608	26,339	80.8%	6,269	19.2%
2007	2	40,960	31,049	75.8%	7,502	18.3%	33,902	26,400	77.9%	7,502	22.1%
2007	3	38,656	29,665	76.7%	6,583	17.0%	31,769	25,186	79.3%	6,583	20.7%
2007	TOTAL	117,378	89,799	76.5%	20,354	17.3%	98,279	77,925	79.3%	20,354	20.7%

WATER AND SEWER USAGE AS BILLED  
ANNUAL SUMMARY  
1997-2017

		WATER					SEWER				
		TOTAL	GENERAL	%	RUGER	%	TOTAL	GENERAL	%	RUGER	%
2008	1	36,702	27,133	73.9%	7,707	21.0%	32,893	25,186	76.6%	7,707	23.4%
2008	2	39,916	29,724	74.5%	7,161	17.9%	34,225	27,064	79.1%	7,161	20.9%
2008	3	45,426	36,921	81.3%	8,505	18.7%	36,594	28,089	76.8%	8,505	23.2%
2008	TOTAL	122,044	93,778	76.8%	23,373	19.2%	103,712	80,339	77.5%	23,373	22.5%
2009	1	38,067	30,360	79.8%	6,038	15.9%	30,427	24,389	80.2%	6,038	19.8%
2009	2	46,249	36,573	79.1%	9,520	20.6%	37,811	28,291	74.8%	9,520	25.2%
2009	3	37,370	29,507	79.0%	6,833	18.3%	29,820	22,987	77.1%	6,833	22.9%
2009	TOTAL	121,686	96,440	79.3%	22,391	18.4%	98,059	75,668	77.2%	22,391	22.8%
2010	1	37,583	29,612	78.8%	6,880	18.3%	30,767	23,887	77.6%	6,880	22.4%
2010	2	39,461	32,628	82.7%	6,833	17.3%	39,516	32,683	82.7%	6,833	17.3%
2010	3	44,955	35,891	79.8%	9,064	20.2%	46,177	37,113	80.4%	9,064	19.6%
2010	TOTAL	121,999	98,131	80.4%	22,777	18.7%	116,459	93,682	80.4%	22,777	19.6%
2011	1	36,798	29,335	79.7%	7,463	20.3%	38,762	31,299	80.7%	7,463	19.3%
2011	2	36,872	28,619	77.6%	8,253	22.4%	33,206	24,953	75.1%	8,253	24.9%
2011	3	42,329	31,557	74.6%	10,772	25.4%	30,895	20,123	65.1%	10,772	34.9%
2011	TOTAL	115,999	89,511	77.2%	26,488	22.8%	102,863	76,375	74.2%	26,488	25.8%
2012	1	39,657	29,270	73.8%	10,480	26.4%	42,242	31,762	75.2%	10,480	24.8%
2012	2	40,165	29,466	73.4%	10,699	26.6%	33,467	22,768	68.0%	10,699	32.0%
2012	3	49,966	33,398	66.8%	16,568	33.2%	34,071	17,503	51.4%	16,568	48.6%
2012	TOTAL	129,788	92,134	71.0%	37,747	29.1%	109,780	72,033	65.6%	37,747	34.4%
2013	1	43,678	30,204	69.2%	13,474	30.8%	38,110	24,636	64.6%	13,474	35.4%
2013	2	41,473	30,005	72.3%	11,468	27.7%	33,406	21,938	65.7%	11,468	34.3%
2013	3	45,391	27,199	59.9%	18,192	40.1%	39,227	21,035	53.6%	18,192	46.4%
2013	TOTAL	130,542	87,408	67.0%	43,134	33.0%	110,743	67,609	61.1%	43,134	38.9%
2014	1	50,322	32,326	64.2%	17,996	35.8%	38,169	20,173	52.9%	17,996	47.1%
2014	2	42,892	27,360	63.8%	18,200	42.4%	38,484	20,284	52.7%	18,200	47.3%
2014	3	43,659	29,712	68.1%	15,851	36.3%	42,443	26,592	62.7%	15,851	37.3%
2014	TOTAL	136,873	89,398	65.3%	52,047	38.0%	119,096	67,049	56.3%	52,047	43.7%
2015	1	43,960	31,097	70.7%	14,128	32.1%	28,397	14,269	50.2%	14,128	49.8%
2015	2	42,192	30,976	73.4%	11,803	28.0%	35,264	23,461	66.5%	11,803	33.5%
2015	3	34,700	25,026	72.1%	9,400	27.1%	38,838	29,438	75.8%	9,400	24.2%
2015	TOTAL	120,852	87,099	72.1%	35,331	29.2%	102,499	67,168	65.5%	35,331	34.5%
2016	1	37,710	26,530	70.4%	11,362	30.1%	31,470	20,108	63.9%	11,362	36.1%
2016	2	44,251	31,107	70.3%	14,661	33.1%	37,902	23,241	61.3%	14,661	38.7%
2016	3	38,037	27,211	71.5%	11,225	29.5%	32,358	21,133	65.3%	11,225	34.7%
2016	TOTAL	119,998	84,848	70.7%	37,248	31.0%	101,730	64,482	63.4%	37,248	36.6%
2017	1	34,558	26,330	76.2%	8,228	23.8%	24,534	16,306	66.5%	8,228	33.5%
2017	2	34,586	28,931	83.6%	5,655	16.4%	27,844	22,189	79.7%	5,655	20.3%
2017	3	30,823	26,231	85.1%	4,592	14.9%	29,084	24,492	84.2%	4,592	15.8%
2017	TOTAL	99,967	81,492	81.5%	18,475	18.5%	81,461	62,986	77.3%	18,475	22.7%

WATER FUND  
BALANCE SHEET AND INCOME STATEMENT  
July 1, 2011 to June 30, 2017

## STATEMENT OF NET POSITION

	June 30, 2012	June 30, 2013	June 30, 2014	June 30, 2015	June 30, 2016	June 30, 2017
CASH & INVESTMENTS	230,973	364,083	497,856	581,757	609,256	686,924
ACCOUNTS RECEIVABLE:	330,029	355,167	407,331	402,754	378,706	307,033
OTHER CURRENT ASSETS	8,486	14,843	32,418	37,469	60,809	73,504
INTERGOVERNMENTAL RECEIVABLE	126,471	109,659	92,847	78,929	65,172	54,310
FIXED ASSETS (NET)	<u>2,575,794</u>	<u>2,458,009</u>	<u>2,338,811</u>	<u>2,219,188</u>	<u>2,127,979</u>	<u>2,036,115</u>
TOTAL ASSETS	<u>3,271,753</u>	<u>3,301,761</u>	<u>3,369,263</u>	<u>3,320,097</u>	<u>3,241,922</u>	<u>3,157,886</u>
MISC CURRENT LIABILITIES	332,008	339,124	312,732	202,783	157,888	130,809
NET PENSION LIABILITY				253,072	325,554	428,456
LONG-TERM DEBT	<u>483,796</u>	<u>404,393</u>	<u>313,888</u>	<u>264,997</u>	<u>153,448</u>	<u>117,241</u>
TOTAL LIABILITIES	<u>815,804</u>	<u>743,517</u>	<u>626,620</u>	<u>720,852</u>	<u>636,890</u>	<u>676,506</u>
NET DEFERRED INFLOWS (OUTFLOWS) OF RESOURCES				(37,703)	(3,101)	89,453
NET POSITION	<u>2,455,949</u>	<u>2,558,244</u>	<u>2,742,643</u>	<u>2,561,542</u>	<u>2,601,931</u>	<u>2,570,833</u>
WORKING CAPITAL	<u>237,480</u>	<u>394,969</u>	<u>624,873</u>	<u>819,197</u>	<u>890,883</u>	<u>936,652</u>

## STATEMENT INCOME, EXPENSES AND CHANGES IN NET POSITION

	Year Ended	June 30, 2012	June 30, 2013	June 30, 2014	June 30, 2015	June 30, 2016	June 30, 2017
REVENUES:							
USER FEES		710,821	823,536	951,779	894,734	801,983	752,811
INTERGOVERNMENTAL		6,572	5,974	5,377	4,779	4,182	3,584
MISCELLANEOUS		3,890	2,741	625	1,132	19,593	1,864
INTEREST		<u>9,832</u>	<u>10,212</u>	<u>276</u>	<u>285</u>	<u>761</u>	<u>1,881</u>
TOTAL REVENUE		<u>731,115</u>	<u>842,463</u>	<u>958,057</u>	<u>900,930</u>	<u>826,519</u>	<u>760,140</u>
EXPENSES:							
OPERATIONS		637,884	604,604	639,628	663,913	659,578	669,578
INTEREST		20,465	17,779	14,833	12,022	9,455	7,213
DEPRECIATION		<u>120,950</u>	<u>117,785</u>	<u>119,197</u>	<u>119,625</u>	<u>117,097</u>	<u>114,447</u>
TOTAL EXPENSE		<u>779,299</u>	<u>740,168</u>	<u>773,658</u>	<u>795,560</u>	<u>786,130</u>	<u>791,238</u>
CHANGE IN NET POSITION		(48,184)	102,295	184,399	105,370	40,389	(31,098)
NET POSITION, BEGINNING (Restated June 30, 2012 and 2015)		<u>2,504,133</u>	<u>2,455,949</u>	<u>2,558,244</u>	<u>2,456,172</u>	<u>2,561,542</u>	<u>2,601,931</u>
NET POSITION, ENDING		<u>2,455,949</u>	<u>2,558,244</u>	<u>2,742,643</u>	<u>2,561,542</u>	<u>2,601,931</u>	<u>2,570,833</u>

## AWWARF RECOMMENDATIONS RESERVES:

OPERATING EXPENSES (12 MOS)	760,140
DEBT SERVICE	43,420
5% REVENUES	<u>37,641</u>
RANGE HIGH	<u>841,201</u>
OPERATING EXPENSES (6 MOS)	380,070
DEBT SERVICE	43,420
5% REVENUES	<u>37,641</u>
RANGE LOW	<u>461,131</u>

## LEVEL OF SERVICE

### Level of Service (LOS) Goals

How do we want the system to perform in the long run?

#### System Reliability

- Analyze the system to determine if assets should be repaired, replaced or reconfigured. For example, can parallel transmission mains be eliminated if a new drinking water source is developed?
- Collect information on watermain breaks, including the impact of outages on customers, and the true cost of repairs. This information allows for informed repair or replace decisions.
- Ensure that financial resources are available to maintain appropriate staffing levels, and to provide staff with the tools and equipment needed to properly maintain the system.
- Ensure that financial resources are available to fund needed asset renewals in a timely manner.

#### Customer Service

- Timely response to customer concerns and complaints.
- Effective recordkeeping and follow-up.
- Accurate billing and cost allocation. Keeping water meters in good working order is essential.
- Keeping customers informed about the condition of the system and asset renewal needs.

## ASSET MANAGEMENT STRATEGIES

### Keys to Successful AM

- Keep it simple
- Form a living document

The following techniques are used to help keep Asset Management a successful on-going process.

- Continually updating the asset inventory and condition of assets over time.
- Update Level of Service Goals over time. Keep consistent with desired performance and customer expectations.
- Continue to improve data collection techniques. Collect information on the condition and performance of assets.
- Repair or replace assets that have a high probability of failure and high consequence of failure.



Brochure produced by:  
May 2019

Portsmouth, NH  
Phone: 603.436.6192  
Concord, NH  
Phone: 603.230.9898

## WATER ASSET MANAGEMENT PROGRAM



## INFO YOU SHOULD KNOW

### What is Asset Management?

Asset Management (AM) planning is a decision-making tool that helps managers determine how to operate and maintain their systems at the lowest cost while maintaining the desired level of service. It consists of the following:

**Asset Inventory and Condition Assessment**—What water system components does the Town own and what condition are they in?

**Level of Service Goals**— What does the Town need to accomplish to deliver the desired level of service to customers?

**Critical Assets and Priority Projects**— Prioritize asset renewals based on the assets importance to the system and its probability of failure.

**Minimum Lifecycle Cost**— Determine the resources needed to operate the system. Are staffing levels adequate? Is staff training and supervision sufficient? Do staff have the tools and supplies they need to properly operate and maintain the system?

**Long-term Funding Strategy**— Are adequate resources available to complete necessary capital projects, including assets renewals?

**Implementation Plan**—What actions are needed to ensure that the asset management plan is continuously updated and maintained?


**Communication Plan**—How will information be shared with the Board of Selectmen and the Public so that they understand the true condition and needs of the water system?

## NEWPORT WATER SYSTEM ASSET INVENTORY

### TOTAL ESTIMATED REPLACEMENT VALUE OF WATER SYSTEM ASSETS

**\$82.6 MILLION**

Water System Component	Estimated Replacement Cost
Water Distribution System	\$76,567,331
Slow Sand Filter Water Treatment Plant	\$2,343,000
Summer Street Storage Tank	\$1,075,000
Water Meters	\$990,000
Pollards Mill Well Facility	\$704,000
Sodium Silicate Building	\$470,000
Vehicles/Equipment	\$340,000
PRV Building	\$85,000
Gilman Pond Water Supply	\$50,000
<b>Grand Total</b>	<b>\$82,624,331</b>



## OVERALL SYSTEM CONDITION

The Town of Newport currently has two water supplies.

- The main water source, Gilman Pond, is located in the Town of Unity. Surface water is treated by a slow-sand filter plant which was built in 1992.
- The Pollards Mill well facility serves as a backup to the main water supply and was built in the late 1960's. It is in need of an upgrade.

**Both the Town's water supplies rely on transmission mains that are over 100 years old.**

- There are two transmission mains from the Gilman Pond water supply to the Pressure Reducing Facility (PRF) on Unity Road. Both of these mains are over 100 years old.
- There are three transmission mains from the PRF to the main service area. Two of the three are over 100 years old.
- The useful life of pipe ranges from about 75 to 120 years, depending on the material, installation conditions, pressures and other factors.

**The Town's distribution mains range in age from over 100 years old to less than one year.**

- While age is not the only indicator of condition, it is typically a factor in pipe failures.
- The Town does have approximately 30,000 feet of cement-lined cast iron pipe installed in the 1960's, which has a significant break history even though it is not near the end of its estimated useful life.

**The Town's water meters are approximately 30 years old and due for replacement.**

Age of Pipe	Length	Percent
Greater than 100 years old	85,766	36%
Between 50 and 100 years old	95,430	41%
Between 20 and 50 years old	41,002	17%
Less than 20 years old	13,393	6%
<b>Grand Total</b>	<b>235,592</b>	<b>100%</b>



## **APPENDIX B**

### **Level of Service Matrix**

## APPENDIX B: LEVEL OF SERVICE GOALS

Goal	Actions	Numerical Target and Timeframe
Collect information on unplanned incidents such as water main breaks or customer complaints.	Record tasks in AxisGIS and download and review on a monthly basis.	Update as needed.
		Download information monthly to review and quantify hours spent on certain items. In particular, time spent finding and repairing water main leaks or breaks.
Regularly inform Town Manager, Selectmen, and general public on the condition and performance of the system.	Combine downloaded information into a management report.	Quarterly or as needed for DPW Director and Town Manager. Annually for Select Board and general public.
Address the back-log of asset renewals.	Prepare a detailed Capital Improvement Plan for the Water System to map out improvements, identify cost saving opportunities, increase redundancy in terms of supply, and reduce the criticality of the Unity Road transmission mains.	Complete by January 2020.
	Include a financial analysis which evaluates rate sufficiency and affordability; and examines opportunities for loan forgiveness.	Update with annual progress reports thereafter.
	Determine an amount to be set aside in capital reserves annually in order to address existing and future capital improvement needs.	Ensure that adequate reserves are being put aside annually.
Ensure that rates are adequate	Perform a rate sufficiency study; adjust rates as needed.	Once every five years
Coordinate infrastructure projects	Complete wastewater and stormwater asset management programs.	By November 2019.
	Coordinate needed upgrades with roadway improvement projects.	

## **APPENDIX C**

### **Attribute Tables and Summaries**

ASSET DATA TABLE							
Asset Description	Type	Subcomponent/Asset ID	Year Installed	Replacement Cost	Useful Life	End Useful Life	Remaining Useful Life
Gilman Pond Water Supply	Intake Screen	Intake Screen	1895	\$ 15,000	40	1935	-84
Gilman Pond Water Supply	Process Piping & Valves	Intake Valve Vault	1992	\$ 35,000	30	2022	3
Slow Sand Filter Water Treatment Plant	WTP Storage	300,000 gal Clearwell	1992	\$ 400,000	75	2067	48
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Sand filter beds and pipe gallery structure	1992	\$ 750,000	100	2092	73
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Concrete block walls	1992	\$ 150,000	75	2067	48
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Wood roof trusses	1992	\$ 75,000	75	2067	48
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Asphalt shingle roof	1992	\$ 50,000	25	2017	-2
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Metals - grating/railings/stairs	1992	\$ 30,000	60	2052	33
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Boiler	1992	\$ 25,000	30	2022	3
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Duct work	1992	\$ 25,000	40	2032	13
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Exhaust fans (4)	1992	\$ 12,000	30	2022	3
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Louvers (5)	1992	\$ 10,000	30	2022	3
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Hot water heaters (5)	1992	\$ 10,000	30	2022	3
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Supply lines/pressure tanks/backflow preventer	1992	\$ 25,000	40	2032	13
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Sump pump	1992	\$ 1,000	10	2002	-17
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Slow sand filter media	1999	\$ 75,000	25	2024	5
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Pump 1	1992	\$ 15,000	25	2017	-2
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Pump 2	1992	\$ 15,000	25	2017	-2
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Tank	1992	\$ 50,000	75	2067	48
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Flow Meter	1992	\$ 10,000	10	2002	-17
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Level Sensor Equipment	1992	\$ 25,000	20	2012	-7
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	4-inch PVC underdrain	1992	\$ 25,000	60	2052	33
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	8-inch PVC underdrain header	1992	\$ 10,000	60	2052	33
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	12-inch DI raw water distribution header	1992	\$ 25,000	60	2052	33
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	Pipe gallery	1992	\$ 75,000	60	2052	33
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Turbidimeter	1992	\$ 5,000	10	2002	-17
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Process Control Panel	1992	\$ 30,000	25	2017	-2
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Level Transmitters (5)	1992	\$ 25,000	15	2007	-12
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Flow Meters (4)	1992	\$ 30,000	15	2007	-12
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Eye wash alarm	1992	\$ 5,000	20	2012	-7
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Fire alarm	1992	\$ 5,000	20	2012	-7
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	Generator	1992	\$ 100,000	25	2017	-2
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	Automatic Transfer Switch	1992	\$ 30,000	25	2017	-2
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	1000 gal Propane Tank (buried)	1992	\$ 25,000	25	2017	-2
Slow Sand Filter Water Treatment Plant	Site Electrical	Electrical Feed	1992	\$ 200,000	50	2042	23
Sodium Silicate Building	Sodium Silicate Building	Metal Roof	1993	\$ 12,000	50	2043	24
Sodium Silicate Building	Sodium Silicate Building	Wood roof trusses	1993	\$ 10,000	60	2053	34
Sodium Silicate Building	Sodium Silicate Building	Brick Walls	1955	\$ 50,000	75	2030	11
Sodium Silicate Building	Sodium Silicate Building	Concrete vault	1955	\$ 100,000	75	2030	11
Sodium Silicate Building	Sodium Silicate Building	Concrete addition	1993	\$ 100,000	75	2068	49
Sodium Silicate Building	Sodium Silicate Building	Metal railings/stairs	1993	\$ 25,000	40	2033	14
Sodium Silicate Building	Chemical Feed System	Sodium Silicate feed pump 1 system	1993	\$ 8,000	15	2008	-11
Sodium Silicate Building	Chemical Feed System	Sodium Silicate bulk tank	1993	\$ 20,000	35	2028	9
Sodium Silicate Building	Chemical Feed System	Sodium Silicate day tank	1993	\$ 10,000	35	2028	9
Sodium Silicate Building	Process Piping	Process Piping	1993	\$ 25,000	50	2043	24
Sodium Silicate Building	Process Valves	Process Valves	1993	\$ 30,000	50	2043	24
Sodium Silicate Building	Site Electrical	Electrical Feed	1993	\$ 80,000	50	2043	24

ASSET DATA TABLE							
Asset Description	Type	Subcomponent/Asset ID	Impact of Failure	Probability of Failure	Risk Score	Criticality	Condition
Gilman Pond Water Supply	Intake Screen	Intake Screen	5.0	5.0	25.0	Highest Risk	
Gilman Pond Water Supply	Process Piping & Valves	Intake Valve Vault	5.0	4.0	20.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	WTP Storage	300,000 gal Clearwell	5.0	2.0	10.0	Frequent Monitoring	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Sand filter beds and pipe gallery structure	3.0	1.0	3.0	Frequent Monitoring	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Concrete block walls	3.0	2.0	6.0	Frequent Monitoring	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Wood roof trusses	4.0	2.0	8.0	Frequent Monitoring	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Asphalt shingle roof	2.0	5.0	10.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Metals - grating/railings/stairs	2.0	2.0	4.0	Limited Monitoring	
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Boiler	5.0	4.0	20.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Duct work	3.0	3.0	9.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Exhaust fans (4)	3.0	4.0	12.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Louvers (5)	1.0	4.0	4.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Hot water heaters (5)	1.0	4.0	4.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Supply lines/pressure tanks/backflow preventer	1.0	3.0	3.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Sump pump	1.0	5.0	5.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Slow sand filter media	3.0	4.0	12.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Pump 1	2.0	5.0	10.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Pump 2	2.0	5.0	10.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Tank	3.0	2.0	6.0	Frequent Monitoring	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Flow Meter	1.0	5.0	5.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Level Sensor Equipment	3.0	5.0	15.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	4-inch PVC underdrain	2.0	2.0	4.0	Limited Monitoring	
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	8-inch PVC underdrain header	2.0	2.0	4.0	Limited Monitoring	
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	12-inch DI raw water distribution header	2.0	2.0	4.0	Limited Monitoring	
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	Pipe gallery	2.0	2.0	4.0	Limited Monitoring	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Turbidimeter	2.0	5.0	10.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Process Control Panel	1.0	5.0	5.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Level Transmitters (5)	1.0	5.0	5.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Flow Meters (4)	1.0	5.0	5.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Eye wash alarm	1.0	5.0	5.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Fire alarm	1.0	5.0	5.0	Priority Renewal	
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	Generator	5.0	5.0	25.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	Automatic Transfer Switch	5.0	5.0	25.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	1000 gal Propane Tank (buried)	3.0	5.0	15.0	Highest Risk	
Slow Sand Filter Water Treatment Plant	Site Electrical	Electrical Feed	2.0	2.0	4.0	Limited Monitoring	
Sodium Silicate Building	Sodium Silicate Building	Metal Roof	2.0	2.0	4.0	Limited Monitoring	
Sodium Silicate Building	Sodium Silicate Building	Wood roof trusses	2.0	2.0	4.0	Limited Monitoring	
Sodium Silicate Building	Sodium Silicate Building	Brick Walls	2.0	3.0	6.0	Priority Renewal	
Sodium Silicate Building	Sodium Silicate Building	Concrete vault	2.0	3.0	6.0	Priority Renewal	
Sodium Silicate Building	Sodium Silicate Building	Concrete addition	2.0	2.0	4.0	Limited Monitoring	
Sodium Silicate Building	Sodium Silicate Building	Metal railings/stairs	2.0	3.0	6.0	Priority Renewal	
Sodium Silicate Building	Chemical Feed System	Sodium Silicate feed pump 1 system	4.0	5.0	20.0	Highest Risk	
Sodium Silicate Building	Chemical Feed System	Sodium Silicate bulk tank	4.0	4.0	16.0	Highest Risk	
Sodium Silicate Building	Chemical Feed System	Sodium Silicate day tank	4.0	4.0	16.0	Highest Risk	
Sodium Silicate Building	Process Piping	Process Piping	2.0	2.0	4.0	Limited Monitoring	
Sodium Silicate Building	Process Valves	Process Valves	2.0	2.0	4.0	Limited Monitoring	
Sodium Silicate Building	Site Electrical	Electrical Feed	2.0	2.0	4.0	Limited Monitoring	

COST OF CRITICAL ASSET REPLACEMENTS - FIRST TEN YEARS												
ASSET DATA TABLE			Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10
Asset Description	Type	Subcomponent/Asset ID	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
Gilman Pond Water Supply	Intake Screen	Intake Screen	\$ 15,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Gilman Pond Water Supply	Process Piping & Valves	Intake Valve Vault	\$ -	\$ -	\$ -	\$ 35,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Storage	300,000 gal Clearwell	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Sand filter beds and pipe gallery structure	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Concrete block walls	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Wood roof trusses	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Asphalt shingle roof	\$ 50,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Metals - grating/railings/stairs	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Boiler	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Duct work	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Exhaust fans (4)	\$ -	\$ -	\$ -	\$ 12,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Louvers (5)	\$ -	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Hot water heaters (5)	\$ -	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Supply lines/pressure tanks/backflow preventer	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Sump pump	\$ 1,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Slow sand filter media	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 75,000	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Pump 1	\$ 15,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Pump 2	\$ 15,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Tank	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Flow Meter	\$ 10,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Level Sensor Equipment	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	4-inch PVC underdrain	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	8-inch PVC underdrain header	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	12-inch DI raw water distribution header	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	Pipe gallery	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Turbidimeter	\$ 5,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Process Control Panel	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Level Transmitters (5)	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Flow Meters (4)	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Eye wash alarm	\$ 5,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Fire alarm	\$ 5,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	Generator	\$ 100,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	Automatic Transfer Switch	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	1000 gal Propane Tank (buried)	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Slow Sand Filter Water Treatment Plant	Site Electrical	Electrical Feed	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Sodium Silicate Building	Metal Roof	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Sodium Silicate Building	Wood roof trusses	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Sodium Silicate Building	Brick Walls	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Sodium Silicate Building	Concrete vault	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Sodium Silicate Building	Concrete addition	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Sodium Silicate Building	Metal railings/stairs	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Chemical Feed System	Sodium Silicate feed pump 1 system	\$ 8,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Chemical Feed System	Sodium Silicate bulk tank	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 20,000
Sodium Silicate Building	Chemical Feed System	Sodium Silicate day tank	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 10,000
Sodium Silicate Building	Process Piping	Process Piping	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Process Valves	Process Valves	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Sodium Silicate Building	Site Electrical	Electrical Feed	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -

ASSET DATA TABLE			COST OF ASSET REPLACEMENTS - NEXT 100 YEARS											
			0 to 10	10 to 20	20 to 30	30 to 40	40 to 50	50 to 60	60 to 70	70 to 80	80 to 90	90 to 100	0 to 100	
Asset Description	Type	Subcomponent/Asset ID	2019-2028	2029-2038	2039-2048	2049-2058	2059-2068	2069-2078	2079-2088	2089-2098	2099-2108	2109-2118	2019-2118	
Gilman Pond Water Supply	Intake Screen	Intake Screen	\$ 15,000	\$ -	\$ -	\$ -	\$ 15,000	\$ -	\$ -	\$ -	\$ 15,000	\$ -	\$ 45,000	
Gilman Pond Water Supply	Process Piping & Valves	Intake Valve Vault	\$ 35,000	\$ -	\$ -	\$ 35,000	\$ -	\$ -	\$ 35,000	\$ -	\$ -	\$ 35,000	\$ 140,000	
Slow Sand Filter Water Treatment Plant	WTP Storage	300,000 gal Clearwell	\$ -	\$ -	\$ -	\$ -	\$ 400,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 400,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Sand filter beds and pipe gallery structure	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 750,000	\$ -	\$ -	\$ 750,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Concrete block walls	\$ -	\$ -	\$ -	\$ -	\$ 150,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 150,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Wood roof trusses	\$ -	\$ -	\$ -	\$ -	\$ 75,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 75,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Asphalt shingle roof	\$ 50,000	\$ -	\$ 50,000	\$ -	\$ -	\$ 50,000	\$ -	\$ 50,000	\$ -	\$ -	\$ 200,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Structural	Metals - grating/railings/stairs	\$ -	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 30,000	\$ 60,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Boiler	\$ 25,000	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ 25,000	\$ 100,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Duct work	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ 25,000	\$ 75,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Exhaust fans (4)	\$ 12,000	\$ -	\$ -	\$ 12,000	\$ -	\$ -	\$ 12,000	\$ -	\$ -	\$ 12,000	\$ 48,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Mechanical	Louvers (5)	\$ 10,000	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ 10,000	\$ 40,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Hot water heaters (5)	\$ 10,000	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ 10,000	\$ 40,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Supply lines/pressure tanks/backflow preventer	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ 25,000	\$ 75,000	
Slow Sand Filter Water Treatment Plant	WTP Building - Plumbing	Sump pump	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 1,000	\$ 10,000	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Slow sand filter media	\$ 75,000	\$ -	\$ -	\$ 75,000	\$ -	\$ 75,000	\$ -	\$ -	\$ 75,000	\$ -	\$ 300,000	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Pump 1	\$ 15,000	\$ -	\$ 15,000	\$ -	\$ -	\$ 15,000	\$ -	\$ 15,000	\$ -	\$ -	\$ 60,000	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Pump 2	\$ 15,000	\$ -	\$ 15,000	\$ -	\$ -	\$ 15,000	\$ -	\$ 15,000	\$ -	\$ -	\$ 60,000	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Recycle Tank	\$ -	\$ -	\$ -	\$ -	\$ 50,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 50,000	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Flow Meter	\$ 10,000	\$ 10,000	\$ 10,000	\$ 10,000	\$ 10,000	\$ 10,000	\$ 10,000	\$ 10,000	\$ 10,000	\$ 10,000	\$ 100,000	
Slow Sand Filter Water Treatment Plant	WTP Process Equipment	Level Sensor Equipment	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ 125,000	
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	4-inch PVC underdrain	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 25,000	\$ 50,000	
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	8-inch PVC underdrain header	\$ -	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ 20,000	
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	12-inch DI raw water distribution header	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 25,000	\$ 50,000	
Slow Sand Filter Water Treatment Plant	Process Valves & Piping	Pipe gallery	\$ -	\$ -	\$ -	\$ 75,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 75,000	\$ 150,000	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Turbidimeter	\$ 5,000	\$ 5,000	\$ 5,000	\$ 5,000	\$ 5,000	\$ 5,000	\$ 5,000	\$ 5,000	\$ 5,000	\$ 5,000	\$ 50,000	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Process Control Panel	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ -	\$ 120,000	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Level Transmitters (5)	\$ 25,000	\$ 25,000	\$ -	\$ 25,000	\$ 25,000	\$ -	\$ 25,000	\$ 25,000	\$ -	\$ 25,000	\$ 175,000	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Flow Meters (4)	\$ 30,000	\$ 30,000	\$ -	\$ 30,000	\$ 30,000	\$ -	\$ 30,000	\$ 30,000	\$ -	\$ 30,000	\$ 210,000	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Eye wash alarm	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 25,000	
Slow Sand Filter Water Treatment Plant	Monitoring & Control	Fire alarm	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 25,000	
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	Generator	\$ 100,000	\$ -	\$ 100,000	\$ -	\$ -	\$ 100,000	\$ -	\$ 100,000	\$ -	\$ -	\$ 400,000	
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	Automatic Transfer Switch	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ -	\$ 120,000	
Slow Sand Filter Water Treatment Plant	Standby Generator and Fuel Storage	1000 gal Propane Tank (buried)	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ -	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ -	\$ 100,000	
Slow Sand Filter Water Treatment Plant	Site Electrical	Electrical Feed	\$ -	\$ -	\$ 200,000	\$ -	\$ -	\$ -	\$ -	\$ 200,000	\$ -	\$ -	\$ 400,000	
Sodium Silicate Building	Sodium Silicate Building	Metal Roof	\$ -	\$ -	\$ 12,000	\$ -	\$ -	\$ -	\$ -	\$ 12,000	\$ -	\$ -	\$ 24,000	
Sodium Silicate Building	Sodium Silicate Building	Wood roof trusses	\$ -	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ 20,000	
Sodium Silicate Building	Sodium Silicate Building	Brick Walls	\$ -	\$ 50,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 50,000	\$ -	\$ 100,000	
Sodium Silicate Building	Sodium Silicate Building	Concrete vault	\$ -	\$ 100,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 100,000	\$ -	\$ 200,000	
Sodium Silicate Building	Sodium Silicate Building	Concrete addition	\$ -	\$ -	\$ -	\$ -	\$ 100,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 100,000	
Sodium Silicate Building	Sodium Silicate Building	Metal railings/stairs	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ 25,000	\$ 75,000	
Sodium Silicate Building	Chemical Feed System	Sodium Silicate feed pump 1 system	\$ 8,000	\$ 8,000	\$ -	\$ 8,000	\$ 8,000	\$ -	\$ 8,000	\$ 8,000	\$ -	\$ 8,000	\$ 56,000	
Sodium Silicate Building	Chemical Feed System	Sodium Silicate bulk tank	\$ 20,000	\$ -	\$ -	\$ -	\$ 20,000	\$ -	\$ -	\$ 20,000	\$ -	\$ -	\$ 60,000	
Sodium Silicate Building	Chemical Feed System	Sodium Silicate day tank	\$ 10,000	\$ -	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ 30,000	
Sodium Silicate Building	Process Piping	Process Piping	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ 50,000	
Sodium Silicate Building	Process Valves	Process Valves	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ 60,000	
Sodium Silicate Building	Site Electrical	Electrical Feed	\$ -	\$ -	\$ 80,000	\$ -	\$ -	\$ -	\$ -	\$ 80,000	\$ -	\$ -	\$ 160,000	

ASSET DATA TABLE							
Asset Description	Type	Subcomponent/Asset ID	Year Installed	Replacement Cost	Useful Life	End Useful Life	Remaining Useful Life
Pollards Mill Well Facility	Pump Building - Structural	Frost wall & footer	1967	\$ 25,000	75	2042	23
Pollards Mill Well Facility	Pump Building - Structural	Floor slab	1967	\$ 10,000	75	2042	23
Pollards Mill Well Facility	Pump Building - Structural	Brick walls	1967	\$ 30,000	75	2042	23
Pollards Mill Well Facility	Pump Building - Structural	Concrete slab roof	1967	\$ 35,000	75	2042	23
Pollards Mill Well Facility	Pump Building - Structural	Membrane roof	1967	\$ 25,000	40	2007	-12
Pollards Mill Well Facility	Pump Building - Mechanical	Electric Heater	1967	\$ 2,000	30	1997	-22
Pollards Mill Well Facility	Pump Building - Mechanical	Louvers (1)	1967	\$ 2,000	30	1997	-22
Pollards Mill Well Facility	Pump Building - Plumbing	Water supply lines	1967	\$ 5,000	40	2007	-12
Pollards Mill Well Facility	Process Valves & Piping	Process Valves & Piping	1967	\$ 30,000	60	2027	8
Pollards Mill Well Facility	Gravel Packed Well	Well #1	1967	\$ 100,000	60	2027	8
Pollards Mill Well Facility	Well	Vertical Turbine Pumps1	1967	\$ 50,000	35	2002	-17
Pollards Mill Well Facility	Standby Generator & ATS	Standby Generator	1967	\$ 100,000	30	1997	-22
Pollards Mill Well Facility	Standby Generator & ATS	Automatic Transfer Switch	1967	\$ 30,000	30	1997	-22
Pollards Mill Well Facility	Standby Generator & ATS	1000 gal Propane Tank (buried)	1967	\$ 25,000	30	1997	-22
Pollards Mill Well Facility	Monitoring & Control	Pump Control Panel	1967	\$ 30,000	20	1987	-32
Pollards Mill Well Facility	Monitoring & Control	Security System	1967	\$ 5,000	20	1987	-32
Pollards Mill Well Facility	Site Electrical	Electrical Feed	1967	\$ 200,000	50	2017	-2
Summer Street Storage Tank	Water Storage Tank	Concrete water storage tank	2000	\$ 1,000,000	75	2075	56
Summer Street Storage Tank	Valve Vault	Vault structure	2000	\$ 10,000	60	2060	41
Summer Street Storage Tank	Valve Vault	Process Piping	2000	\$ 20,000	75	2075	56
Summer Street Storage Tank	Valve Vault	Process Valves	2000	\$ 15,000	40	2040	21
Summer Street Storage Tank	Site Electrical	Site Electrical	2000	\$ 30,000	50	2050	31
PRV Building	PRV Vault	PRV Vault	1934	\$ 25,000	75	2009	-10
PRV Building	PRV Building	PRV Building	1934	\$ 15,000	75	2009	-10
PRV Building	Process Valves & Piping	Process Valves & Piping	1934	\$ 30,000	60	1994	-25
PRV Building	Controls	Controls	1934	\$ 15,000	15	1949	-70
Vehicles/Equipment	Chevy Pickup	W-1	2009	\$ 40,000	20	2029	10
Vehicles/Equipment	Chevy 1-Ton Dump	W-2	2017	\$ 45,000	20	2037	18
Vehicles/Equipment	Dodge Utility Trk	W-3	2017	\$ 40,000	20	2037	18
Vehicles/Equipment	Case Backhoe	W-4	2001	\$ 45,000	20	2021	2
Vehicles/Equipment	Sullivan Air Comp	W-5	1993	\$ 20,000	20	2013	-6
Vehicles/Equipment	SRECO Sewer Rodder	W-6	1989	\$ 7,000	20	2009	-10
Vehicles/Equipment	Ray-Tech Infrared	W-7	1991	\$ 25,000	20	2011	-8
Vehicles/Equipment	Obm Sewer Jetter	W-8	2013	\$ 40,000	20	2033	14
Vehicles/Equipment	John Deere Loader	W-9	1999	\$ 45,000	20	2019	0
Vehicles/Equipment	Sylvan Seabreeze Sealite	W-10	2013	\$ 3,000	20	2033	14
Vehicles/Equipment	Ford Ltd. Crown Victoria	W-11	2011	\$ 30,000	20	2031	12
Water Meters	Water Meters	Water Meters	1989	\$ 990,000	15	2004	-15




ASSET DATA TABLE						
Asset Description	Type	Subcomponent/Asset ID	Impact of Failure	Probability of Failure	Risk Score	Criticality
Pollards Mill Well Facility	Pump Building - Structural	Frost wall & footer	3.0	2.0	6.0	Frequent Monitoring
Pollards Mill Well Facility	Pump Building - Structural	Floor slab	2.0	2.0	4.0	Limited Monitoring
Pollards Mill Well Facility	Pump Building - Structural	Brick walls	3.0	2.0	6.0	Frequent Monitoring
Pollards Mill Well Facility	Pump Building - Structural	Concrete slab roof	3.0	2.0	6.0	Frequent Monitoring
Pollards Mill Well Facility	Pump Building - Structural	Membrane roof	1.0	5.0	5.0	Priority Renewal
Pollards Mill Well Facility	Pump Building - Mechanical	Electric Heater	1.0	5.0	5.0	Priority Renewal
Pollards Mill Well Facility	Pump Building - Mechanical	Louvers (1)	1.0	5.0	5.0	Priority Renewal
Pollards Mill Well Facility	Pump Building - Plumbing	Water supply lines	1.0	5.0	5.0	Priority Renewal
Pollards Mill Well Facility	Process Valves & Piping	Process Valves & Piping	1.0	4.0	4.0	Priority Renewal
Pollards Mill Well Facility	Gravel Packed Well	Well #1	3.0	4.0	12.0	Highest Risk
Pollards Mill Well Facility	Well	Vertical Turbine Pumps1	2.0	5.0	10.0	Priority Renewal
Pollards Mill Well Facility	Standby Generator & ATS	Standby Generator	2.0	5.0	10.0	Priority Renewal
Pollards Mill Well Facility	Standby Generator & ATS	Automatic Transfer Switch	2.0	5.0	10.0	Priority Renewal
Pollards Mill Well Facility	Standby Generator & ATS	1000 gal Propane Tank (buried)	2.0	5.0	10.0	Priority Renewal
Pollards Mill Well Facility	Monitoring & Control	Pump Control Panel	2.0	5.0	10.0	Priority Renewal
Pollards Mill Well Facility	Monitoring & Control	Security System	2.0	5.0	10.0	Priority Renewal
Pollards Mill Well Facility	Site Electrical	Electrical Feed	2.0	5.0	10.0	Priority Renewal
Summer Street Storage Tank	Water Storage Tank	Concrete water storage tank	5.0	1.0	5.0	Frequent Monitoring
Summer Street Storage Tank	Valve Vault	Vault structure	1.0	2.0	2.0	Limited Monitoring
Summer Street Storage Tank	Valve Vault	Process Piping	4.0	1.0	4.0	Frequent Monitoring
Summer Street Storage Tank	Valve Vault	Process Valves	5.0	2.0	10.0	Frequent Monitoring
Summer Street Storage Tank	Site Electrical	Site Electrical	5.0	2.0	10.0	Frequent Monitoring
PRV Building	PRV Vault	PRV Vault	5.0	5.0	25.0	Highest Risk
PRV Building	PRV Building	PRV Building	3.0	5.0	15.0	Highest Risk
PRV Building	Process Valves & Piping	Process Valves & Piping	4.0	5.0	20.0	Highest Risk
PRV Building	Controls	Controls	5.0	5.0	25.0	Highest Risk
Vehicles/Equipment	Chevy Pickup	W-1	2.0	4.0	8.0	Priority Renewal
Vehicles/Equipment	Chevy 1-Ton Dump	W-2	3.0	3.0	9.0	Highest Risk
Vehicles/Equipment	Dodge Utility Trk	W-3	4.0	3.0	12.0	Highest Risk
Vehicles/Equipment	Case Backhoe	W-4	3.0	4.0	12.0	Highest Risk
Vehicles/Equipment	Sullivan Air Comp	W-5	3.0	5.0	15.0	Highest Risk
Vehicles/Equipment	SRECO Sewer Rodder	W-6	3.0	5.0	15.0	Highest Risk
Vehicles/Equipment	Ray-Tech Infrared	W-7	3.0	5.0	15.0	Highest Risk
Vehicles/Equipment	Obm Sewer Jetter	W-8	3.0	3.0	9.0	Highest Risk
Vehicles/Equipment	John Deere Loader	W-9	3.0	5.0	15.0	Highest Risk
Vehicles/Equipment	Sylvan Seabreeze Sealite	W-10	2.0	3.0	6.0	Priority Renewal
Vehicles/Equipment	Ford Ltd. Crown Victoria	W-11	2.0	3.0	6.0	Priority Renewal
Water Meters	Water Meters	Water Meters	3.0	5.0	15.0	Highest Risk


COST OF CRITICAL ASSET REPLACEMENTS - FIRST TEN YEARS													
ASSET DATA TABLE				Year 1	Year 2	Year 3	Year 4	Year 5	Year 6	Year 7	Year 8	Year 9	Year 10
Asset Description	Type	Subcomponent/Asset ID	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
Pollards Mill Well Facility	Pump Building - Structural	Frost wall & footer	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Pump Building - Structural	Floor slab	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Pump Building - Structural	Brick walls	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Pump Building - Structural	Concrete slab roof	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Pump Building - Structural	Membrane roof	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Pump Building - Mechanical	Electric Heater	\$ 2,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Pump Building - Mechanical	Louvers (1)	\$ 2,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Pump Building - Plumbing	Water supply lines	\$ 5,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Process Valves & Piping	Process Valves & Piping	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 30,000	\$ -
Pollards Mill Well Facility	Gravel Packed Well	Well #1	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 100,000	\$ -
Pollards Mill Well Facility	Well	Vertical Turbine Pumps1	\$ 50,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Standby Generator & ATS	Standby Generator	\$ 100,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Standby Generator & ATS	Automatic Transfer Switch	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Standby Generator & ATS	1000 gal Propane Tank (buried)	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Monitoring & Control	Pump Control Panel	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Monitoring & Control	Security System	\$ 5,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Pollards Mill Well Facility	Site Electrical	Electrical Feed	\$ 200,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Summer Street Storage Tank	Water Storage Tank	Concrete water storage tank	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Summer Street Storage Tank	Valve Vault	Vault structure	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Summer Street Storage Tank	Valve Vault	Process Piping	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Summer Street Storage Tank	Valve Vault	Process Valves	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Summer Street Storage Tank	Site Electrical	Site Electrical	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PRV Building	PRV Vault	PRV Vault	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PRV Building	PRV Building	PRV Building	\$ 15,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PRV Building	Process Valves & Piping	Process Valves & Piping	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PRV Building	Controls	Controls	\$ 15,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Chevy Pickup	W-1	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Chevy 1-Ton Dump	W-2	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Dodge Utility Trk	W-3	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Case Backhoe	W-4	\$ -	\$ -	\$ 45,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Sullivan Air Comp	W-5	\$ 20,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	SRECO Sewer Rodder	W-6	\$ 7,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Ray-Tech Infrared	W-7	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Obm Sewer Jetter	W-8	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	John Deere Loader	W-9	\$ 45,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Sylvan Seabreeze Sealite	W-10	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Vehicles/Equipment	Ford Ltd. Crown Victoria	W-11	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Water Meters	Water Meters	Water Meters	\$ 990,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -

ASSET DATA TABLE			COST OF ASSET REPLACEMENTS - NEXT 100 YEARS											
			0 to 10	10 to 20	20 to 30	30 to 40	40 to 50	50 to 60	60 to 70	70 to 80	80 to 90	90 to 100	0 to 100	
Asset Description	Type	Subcomponent/Asset ID	2019-2028	2029-2038	2039-2048	2049-2058	2059-2068	2069-2078	2079-2088	2089-2098	2099-2108	2109-2118	2019-2118	
Pollards Mill Well Facility	Pump Building - Structural	Frost wall & footer	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 25,000	\$ 50,000	
Pollards Mill Well Facility	Pump Building - Structural	Floor slab	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ 20,000	
Pollards Mill Well Facility	Pump Building - Structural	Brick walls	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 30,000	\$ 60,000	
Pollards Mill Well Facility	Pump Building - Structural	Concrete slab roof	\$ -	\$ -	\$ 35,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 35,000	\$ 70,000	
Pollards Mill Well Facility	Pump Building - Structural	Membrane roof	\$ 25,000	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ 75,000	
Pollards Mill Well Facility	Pump Building - Mechanical	Electric Heater	\$ 2,000	\$ -	\$ -	\$ 2,000	\$ -	\$ -	\$ 2,000	\$ -	\$ -	\$ 2,000	\$ 8,000	
Pollards Mill Well Facility	Pump Building - Mechanical	Louvers (1)	\$ 2,000	\$ -	\$ -	\$ 2,000	\$ -	\$ -	\$ 2,000	\$ -	\$ -	\$ 2,000	\$ 8,000	
Pollards Mill Well Facility	Pump Building - Plumbing	Water supply lines	\$ 5,000	\$ -	\$ -	\$ -	\$ 5,000	\$ -	\$ -	\$ -	\$ 5,000	\$ -	\$ 15,000	
Pollards Mill Well Facility	Process Valves & Piping	Process Valves & Piping	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ -	\$ 60,000	
Pollards Mill Well Facility	Gravel Packed Well	Well #1	\$ 100,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 100,000	\$ -	\$ -	\$ -	\$ 200,000	
Pollards Mill Well Facility	Well	Vertical Turbine Pumps1	\$ 50,000	\$ -	\$ -	\$ 50,000	\$ -	\$ -	\$ -	\$ 50,000	\$ -	\$ -	\$ 150,000	
Pollards Mill Well Facility	Standby Generator & ATS	Standby Generator	\$ 100,000	\$ -	\$ -	\$ 100,000	\$ -	\$ -	\$ 100,000	\$ -	\$ -	\$ 100,000	\$ 400,000	
Pollards Mill Well Facility	Standby Generator & ATS	Automatic Transfer Switch	\$ 30,000	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ 30,000	\$ 120,000	
Pollards Mill Well Facility	Standby Generator & ATS	1000 gal Propane Tank (buried)	\$ 25,000	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ 25,000	\$ 100,000	
Pollards Mill Well Facility	Monitoring & Control	Pump Control Panel	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ 150,000	
Pollards Mill Well Facility	Monitoring & Control	Security System	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 5,000	\$ -	\$ 25,000	
Pollards Mill Well Facility	Site Electrical	Electrical Feed	\$ 200,000	\$ -	\$ -	\$ -	\$ -	\$ 200,000	\$ -	\$ -	\$ -	\$ -	\$ 400,000	
Summer Street Storage Tank	Water Storage Tank	Concrete water storage tank	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,000,000	\$ -	\$ -	\$ -	\$ -	\$ 1,000,000	
Summer Street Storage Tank	Valve Vault	Vault structure	\$ -	\$ -	\$ -	\$ -	\$ 10,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 10,000	
Summer Street Storage Tank	Valve Vault	Process Piping	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 20,000	\$ -	\$ -	\$ -	\$ -	\$ 20,000	
Summer Street Storage Tank	Valve Vault	Process Valves	\$ -	\$ -	\$ 15,000	\$ -	\$ -	\$ -	\$ 15,000	\$ -	\$ -	\$ -	\$ 30,000	
Summer Street Storage Tank	Site Electrical	Site Electrical	\$ -	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ 30,000	\$ -	\$ 60,000	
PRV Building	PRV Vault	PRV Vault	\$ 25,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 25,000	\$ -	\$ -	\$ 50,000	
PRV Building	PRV Building	PRV Building	\$ 15,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 15,000	\$ -	\$ -	\$ 30,000	
PRV Building	Process Valves & Piping	Process Valves & Piping	\$ 30,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 30,000	\$ -	\$ -	\$ -	\$ 60,000	
PRV Building	Controls	Controls	\$ 15,000	\$ 15,000	\$ -	\$ 15,000	\$ 15,000	\$ -	\$ 15,000	\$ 15,000	\$ -	\$ 15,000	\$ 105,000	
Vehicles/Equipment	Chevy Pickup	W-1	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ 200,000	
Vehicles/Equipment	Chevy 1-Ton Dump	W-2	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ 225,000	
Vehicles/Equipment	Dodge Utility Trk	W-3	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ 200,000	
Vehicles/Equipment	Case Backhoe	W-4	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 225,000	
Vehicles/Equipment	Sullivan Air Comp	W-5	\$ 20,000	\$ -	\$ 20,000	\$ -	\$ 20,000	\$ -	\$ 20,000	\$ -	\$ 20,000	\$ -	\$ 100,000	
Vehicles/Equipment	SRECO Sewer Rodder	W-6	\$ 7,000	\$ -	\$ 7,000	\$ -	\$ 7,000	\$ -	\$ 7,000	\$ -	\$ 7,000	\$ -	\$ 35,000	
Vehicles/Equipment	Ray-Tech Infrared	W-7	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ 25,000	\$ -	\$ 125,000	
Vehicles/Equipment	Obm Sewer Jetter	W-8	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ -	\$ 40,000	\$ 200,000	
Vehicles/Equipment	John Deere Loader	W-9	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 45,000	\$ -	\$ 225,000	
Vehicles/Equipment	Sylvan Seabreeze Sealite	W-10	\$ -	\$ 3,000	\$ -	\$ 3,000	\$ -	\$ 3,000	\$ -	\$ 3,000	\$ -	\$ 3,000	\$ 15,000	
Vehicles/Equipment	Ford Ltd. Crown Victoria	W-11	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ -	\$ 30,000	\$ 150,000	
Water Meters	Water Meters	Water Meters	\$ 990,000	\$ 990,000	\$ -	\$ 990,000	\$ 990,000	\$ -	\$ 990,000	\$ 990,000	\$ -	\$ 990,000	\$ 6,930,000	

Row Labels	Sum of Replacement Cost
Slow Sand Filter Water Treatment Plant	2,343,000
Summer Street Storage Tank	1,075,000
Pollards Mill Well Facility	704,000
Sodium Silicate Building	470,000
PRV Building	85,000
Gilman Pond Water Supply	50,000
Grand Total	4,727,000




Row Labels	Sum of Replacement Cost
Water Distribution System	\$76,567,331
Water Meters	\$990,000
Vertical Assets	\$4,727,000
Vehicles/Equipment	\$340,000
Grand Total	\$82,624,331



Row Labels	Sum of 2019-2028
Water Distribution System	\$28,543,467
Water Meters	\$990,000
Pollards Mill Well Facility	\$604,000
Slow Sand Filter Water Treatment Plant	\$503,000
Vehicles/Equipment	\$142,000
PRV Building	\$85,000
Gilman Pond Water Supply	\$50,000
Sodium Silicate Building	\$38,000
Summer Street Storage Tank	\$0
Grand Total	\$30,955,467


Row Labels	Sum of 2019-2028
25.0	\$7,194,274
Gilman Pond Water Supply	\$15,000
PRV Building	\$40,000
Slow Sand Filter Water Treatment Plant	\$130,000
Water Distribution System	\$7,009,274
20.0	\$9,859,956
Gilman Pond Water Supply	\$35,000
PRV Building	\$30,000
Slow Sand Filter Water Treatment Plant	\$25,000
Sodium Silicate Building	\$8,000
Water Distribution System	\$9,761,956
16.0	\$4,465,794
Sodium Silicate Building	\$30,000
Water Distribution System	\$4,435,794
15.0	\$4,142,969
PRV Building	\$15,000
Slow Sand Filter Water Treatment Plant	\$50,000
Water Distribution System	\$2,990,969
Vehicles/Equipment	\$97,000
Water Meters	\$990,000
12.0	\$2,140,188
Pollards Mill Well Facility	\$100,000
Slow Sand Filter Water Treatment Plant	\$87,000
Water Distribution System	\$1,908,188
Vehicles/Equipment	\$45,000
10.0	\$2,026,748
Pollards Mill Well Facility	\$440,000
Slow Sand Filter Water Treatment Plant	\$85,000
Water Distribution System	\$1,501,748
5.0	\$690,204
Pollards Mill Well Facility	\$34,000
Slow Sand Filter Water Treatment Plant	\$106,000
Water Distribution System	\$550,204
4.0	\$435,334
Pollards Mill Well Facility	\$30,000
Slow Sand Filter Water Treatment Plant	\$20,000
Water Distribution System	\$385,334
Grand Total	\$30,955,467

	Column Labels									
Values	Water Distrik	Water Meters	Pollards Mill Well Facility	Slow Sand Filter Water Treatment Plant	Vehicles/Equipment	PRV Building	Gilman Pond Water Supply	Sodium Silicate Building	Summer Street Storage Tank	Grand Total
Sum of 2019-2028	\$28,543,467	\$990,000	\$604,000	\$503,000	\$142,000	\$85,000	\$50,000	\$38,000	\$0	\$30,955,467
Sum of 2029-2038	\$6,709,384	\$990,000	\$0	\$121,000	\$198,000	\$15,000	\$0	\$183,000	\$0	\$8,216,384
Sum of 2039-2048	\$8,659,985	\$0	\$135,000	\$516,000	\$142,000	\$0	\$0	\$147,000	\$15,000	\$9,614,985
Sum of 2049-2058	\$4,114,480	\$990,000	\$209,000	\$368,000	\$198,000	\$15,000	\$35,000	\$18,000	\$30,000	\$5,977,480
Sum of 2059-2068	\$1,920,111	\$990,000	\$65,000	\$781,000	\$142,000	\$15,000	\$15,000	\$138,000	\$10,000	\$4,076,111



Values	
Sum of 2019-2028	\$30,955,467
Sum of 2029-2038	\$8,216,384
Sum of 2039-2048	\$9,614,985
Sum of 2049-2058	\$5,977,480
Sum of 2059-2068	\$4,076,111
Sum of 2019-2068	\$58,840,427

Column Labels											
Values	Gilman Pond Water Supply	Pollards Mill Well Facility	PRV Building	Slow Sand Filter Water Treatment Plant	Sodium Silicate Building	Summer Street Storage Tank	Water Distribution System	Vehicles/Equipment	Water Meters		
2019-2028	\$50,000	\$604,000	\$85,000		\$503,000	\$38,000	\$0	\$28,543,467	\$142,000	\$990,000	\$30,955,467
2029-2038	\$0	\$0	\$15,000		\$121,000	\$183,000	\$0	\$6,709,384	\$198,000	\$990,000	\$8,216,384
2039-2048	\$0	\$135,000	\$0		\$516,000	\$147,000	\$15,000	\$8,659,985	\$142,000	\$0	\$9,614,985
2049-2058	\$35,000	\$209,000	\$15,000		\$368,000	\$18,000	\$30,000	\$4,114,480	\$198,000	\$990,000	\$5,977,480
2059-2068	\$15,000	\$65,000	\$15,000		\$781,000	\$138,000	\$10,000	\$1,920,111	\$142,000	\$990,000	\$4,076,111
2069-2078	\$0	\$200,000	\$0		\$406,000	\$25,000	\$1,020,000	\$3,487,483	\$198,000	\$0	\$5,336,483
2079-2088	\$35,000	\$324,000	\$45,000		\$163,000	\$8,000	\$15,000	\$14,155,271	\$142,000	\$990,000	\$15,877,271
2089-2098	\$0	\$50,000	\$55,000		\$1,286,000	\$185,000	\$0	\$6,428,843	\$198,000	\$990,000	\$9,192,843
2099-2108	\$15,000	\$65,000	\$0		\$126,000	\$150,000	\$30,000	\$1,495,526	\$142,000	\$0	\$2,023,526
2109-2118	\$35,000	\$259,000	\$15,000		\$343,000	\$43,000	\$0	\$5,816,429	\$198,000	\$990,000	\$7,699,429
	\$185,000	\$1,911,000	\$245,000		\$4,613,000	\$935,000	\$1,120,000	\$81,330,978	\$1,700,000	\$6,930,000	\$98,969,978



Values	
2019-2028	\$30,955,467
2029-2038	\$8,216,384
2039-2048	\$9,614,985
2049-2058	\$5,977,480
2059-2068	\$4,076,111
2069-2078	\$5,336,483
2079-2088	\$15,877,271
2089-2098	\$9,192,843
2099-2108	\$2,023,526
2109-2118	\$7,699,429
2019-2118	\$98,969,978



## **APPENDIX D**

### **Instruction Sheets**

## **FIELD DATA COLLECTION**


Field data will be completed using the AxisGIS system. The following files have been provided to the Town as part of their Asset Management Program.

## **ArcMAP FILES**

### *File Geodatabases:*

The following “Newport\_water” File Geodatabase contains the Town’s water system inventory information has been provided as listed in Figure D-2 below.

**Figure D- 1. List of Feature Classes stored in Newport\_Water\_System File Geodatabase**




The main file is the “Newport\_watermains” feature class. This file contains the bulk of the information on the Town’s water system inventory, such as estimated age, material, remaining useful life, etc.

The information came from a variety of sources including a system-wide report completed in 2009, field data collected in 2009, field data collected in 2018-2019, and staff review comments.

This geodatabase has been provided to the Town in electronic format and may be uploaded to the Town’s AxisGIS account.

Several “background” files have been provided as well, including such items as town boundaries, water bodies, roads and parcels. These are stored in the “Newport\_Background” file geodatabase and are listed below.

**Figure D- 2. List of Feature Classes stored in Newport\_Background File Geodatabase**



*Map (mxd) files and Layer files:*


The data is displayed in .mxd files. The various maps (or .mxd files) display the data in various ways. Paper versions have been provided in Appendix E, and are listed below.

**Figure D- 3. List of Map Files**



Each of the maps has different symbology. For instance, Map E2 displays the water system by pipe diameter and Map E4 displays the water system by the year installed. Layer files enable the user to quickly change the parameters shown on the map. The layer files provided are listed in Figure D-4 below.


**Figure D- 4. List of Layer Files**



*Tools and Scripts:*

Various tools have been provided to allow the Town to easily update and export data from the “Newport\_watermains” feature class and other files as desired. These are listed in Figure D-5.

**Figure D- 5. List of Tools and Scripts**



Field names, descriptions and types for the watermain feature class are provided in Table D-1 below.

**Table D- 1. Water Pipe Feature Class Fields**

<b>Name</b>	<b>Alias</b>	<b>Type</b>	<b>Length</b>
OBJECTID	OBJECTID	OID	4
Shape	Shape	Geometry	0
Pipe_ID	Pipe_ID	String	10
Remarks	Remarks	String	254
Street	Street	String	254
Loc_descr	Loc_descr	String	254
Year_txt	Year_txt	String	254
Diameter	Diameter	Double	8
Material	Material	String	254
Model_len	Model_len	Double	8
Source	Source	String	254
Comment1	Comment1	String	254
Comment2	Comment2	String	254
Shape_Length	Shape_Length	Double	8
Rec_Comm	Rec_Comm	String	255
Type	Type	String	50
Year_in	Year_in	SmallInteger	2
U_life	Estimated Useful Life	SmallInteger	2
EU_life	EU_life	SmallInteger	2
RU_life	RU_life	SmallInteger	2
Impact	Impact of Failure	Double	8
Prob	Probability of Failure	Double	8
Cond_Score	Condition Score	Double	8
Risk_Score	Risk Score	Double	8
Crit	Criticality	String	50
Repl_year	Replacement Year	SmallInteger	2
Repl_cost	Replacement Cost	Double	8
Cap_plans	Cap_plans	String	250
Redundancy	Redundancy	String	250

Tools have been provided which enable the user to quickly update certain fields or export data to Excel spreadsheets. Screenshots of tool interfaces and Tool Diagrams are provided below.

00\_Calculate\_WaterMain

Unit Cost

Current Year

Newport\_watermain

N:\PROJECTS\NEWPORT, NH\REALNUM\2382 Water AMP Program\08\_Comp\New

OK Cancel Environments... << Hide Help Tool Help

00\_Calculate\_WaterMain

01\_Tables\_to\_Excel

Feature Class



Spreadsheet\_name


Folder

OK Cancel Environments... << Hide Help Tool Help


01\_Tables\_to\_Excel


Export Sewer Pipe attribute table to Excel.














## **FINANCIAL PLANNING AND INVENTORY SPREADSHEET**

The Financial Planning and Inventory Spreadsheet has been provided to assist the Town with long-term planning. An explanation of the spreadsheet and how it works has been provided below.

**Asset Data Table:** This tab contains information on the vertical asset subcomponents (ie. pumps, wells, storage tanks, treatment facilities, building components, etc.) and each water main segment.

The first 13 columns are listed are similar to the feature class fields listed in Tables D-1 and D-2 above. They are listed below.

Asset Description  
Type  
Subcomponent/Asset ID  
Year Installed  
Replacement Cost  
Useful Life  
End Useful Life  
Remaining Useful Life  
Impact of Failure  
Probability of Failure  
Risk Score  
Criticality  
Condition

**Replacement Schedule:** These 20 columns are normally hidden. Formulas in these cells schedule out the year replacements are due, up to 20 replacements. This assumes that no assets with a useful life of less than 5 years will be included. If the Town wants to schedule out assets with useful lives less than five years, the spreadsheet can be modified to accommodate that.

**Estimated Cost of Replacements Over Ten Years** - formula computes the estimated cost of replacements each year for the next ten years. Note that the years in the headings are automatically recalculated when cell "A2" (Year 1) is revised.

**Estimated Cost of Replacements Over One-hundred Years** - formula computes the estimated cost of replacements each decade for the next one hundred years. Note that the ten-year time frames in the headings are automatically recalculated when cell "A2" (Year 1) is revised.

**Inventory Overview:** This tab totals up the estimated replacement cost for the entire system using a pivot table and pivot chart. In some cases, the assets have been grouped into broader categories (ie. vertical assets).

**Ten-Year Look Ahead:** This tab contains the following pivot tables, which detail replacement costs for the next ten years.

- A summary of estimated replacement costs over the next ten years by year.
- A summary of estimated replacement costs over the next ten years by risk score.

If the "Data Table" is modified, then this summary table can be updated simply by clicking the "Analyze" tab at the top of the spreadsheet and then clicking "Refresh". If records are added to or removed from the "Data Table", then choose "Change Data Source" to make sure all records are included.

**Fifty-Year Look Ahead:** This tab includes a pivot chart of replacement costs over the next five decades. It can be updated in the same manner as the "Ten-Year Detail" and all other pivot tables and charts in the spreadsheet.

**One Hundred-Year Look Ahead:** This tab includes a table and a bar chart which summarize replacement costs for the next hundred years by decade.

### **ASSET DATA TABLE FORMULA SUMMARY**

---

Columns G through M contain formulas to compute such parameters as "Remaining Useful Life" for vertical assets. These same parameters are computed for water mains using Tools in ArcGIS.

Columns N through BB contain formulas which schedule out replacement costs for both horizontal and vertical assets over a time span of 100 years to assist in financial planning.

Column G: End of Useful Life

Equal to Year Installed + Useful Life

Column H: Remaining Useful Life

Equal to End of Useful Life – Current Year (Cell A2)

Column I: Impact of Failure

Assigned by user.

Column J: Probability of Failure

If there is no Condition Score (Column M) then Probability of Failure is computed based on Remaining Useful Life as shown in Table D-3.

If there is a Condition Score, then Probability of Failure equals the Condition Score.

**Table D- 2. Probability of Failure (Condition) Score Based on Remaining Useful Life**

<b>Condition Score</b>	<b>General Description</b>
5.0	Remaining Useful Life <= 0
4.0	Remaining Useful Life > 0 and <= 10
3.0	Remaining Useful Life > 10 and <= 20
2.0	Remaining Useful Life > 20 and <= 50
1.0	Remaining Useful Life > 50

Column K: Risk Score

Probability of Failure x Impact of Failure

Column L: Criticality

If Probability of Failure and Impact of Failure are both  $\geq 2.5$ , then "Highest Risk".

If Probability of Failure  $\geq 2.5$  and Impact of Failure  $< 2.5$ , then "Priority Renewal"

If Probability of Failure  $< 2.5$  and Impact of Failure  $\geq 2.5$ , then "Frequent Monitoring"

If Probability of Failure and Impact of Failure  $< 2.5$ , then "Limited Monitoring"

Column M: Condition Score

The Condition Score of an asset is assigned by Town staff and overrides its Remaining Useful Life in determining its Probability of Failure. For instance, if an asset has twenty (20) years of remaining useful life, its Probability of Failure Score will be 3. However, if the asset is in poor condition, and is assigned a Condition Score of 5, the Condition Score will override the calculated Probability of Failure Score. It's Probability of Failure will be 5, not 3.

Column N: First replacement

If End of Useful Life is less than the Current Year, then first replacement is scheduled to occur in the current year. Otherwise, First Replacement = End of Useful Life.

Column O-AG: Subsequent replacements

If the prior replacement is "0", then "0". If the prior replacement + Current Useful Life falls outside the 100-year time frame, then "0".

If neither of these is true (ie. the next replacement falls between Year 1 and Year 100), then the replacement is scheduled for the prior replacement + Current Useful Life.

Column AH - AQ: Schedule out replacement cost for the next ten years -

Compare the year in the header row to the scheduled replacements for a given asset. If there's a match then populate the cell with the replacement cost.

Column AR - BA: Schedule out replacement cost for the next hundred years -

Compare the year in the upper header row (ie. beginning of ten-year period) and the lower header row (ie. the end of the ten-year period) to the scheduled replacements for a given asset. If there's a match then populate with the replacement cost.

Column BB: Sum Columns AR through BA to determine replacement costs for the next 100 years.

## **APPENDIX E**

### **Water System Maps**



