Town of Newport, New Hampshire Building Assessment | July 31, 2017



Building: Pollards Well

Newport, New Hampshire

Con	dition
1	Fully operational, new, recently replaced
2	Fully operational, 0-25% of life expectancy used, no issues, no concerns,
3	Fully operational, 25-50% life expectancy used, periodic problems
4	Operational, 50-75% life expectancy used, occasional problems, frequent repairs needed
5	Operational only with constant attention, 100% life expectancy used, failure imminent

Priority is scaled 1-10 with 1 being urgent

Architectural							
	Brick building housing well p	ump . Utilitarian, cou		iintenance ou	tlined in the rep	port	
	Equipment	Condition	Est. Remaining Service Life	Priority	Cost Estimate	Remarks & Recommendations	Photos
	751,Exterior Note:	2	50	7	\$250	Install down spout to scupper.	

equipment	condition	Est remaining Service life	priority	cost	remarks &recommendations	
750,Exterior Note:	4	8	3	\$2.50 sq.ft	Paint door and frame, clean vent.	
749,Exterior Note:	4	8	4	\$1,000	Remove dirt to show 6" of foundation grade swale to drain to rear.	
526,Exterior Brick	3	50	5	\$5.00 sq.ft.	Re-point brick. under old electrical service entry at rear corner	
746,Exterior Brick	4	50	7	\$1.50 sq.ft.	Clean brick	KOHLER

	equipment	condition	Est remaining Service life	priority	cost	remarks &recommendations		
Structural								
	8" of concrete masonry const The roof structure was not acc and foundations are of reinfo	bearing. The interiors ruction, with a 4"exte cessible for inspection rced concrete constru	surfaces of the rior brick vene n as it is concea action. The orig	perimeter wa eer. aled by a plast ginal date of c	Ils are conceale er ceiling, it is b onstruction is n	ed by wood paneling. The structu believed to be framed using dime	nsional lumber rafters clear spanning th	or inspection, but they are believed to be of se 14' dimension of the building. The floor
	Equipment	Condition	Est. Remaining Service Life	Priority	Cost Estimate	Remarks & Recommendations		

Mechanical						
	Equipment	Condition	Est. Remaining Service Life Priority	Cost Estimate	Remarks & Recommendations	
	254,Fire Hydrant					

equipment		condition	Est remaining Service life	priority	cost	remarks &recommendations	
252,1000 mounted I	Gallon pad LP tank					Supplies gas for generator. Unknown if gas supplier maintains tank or if tank is town owned. Unknown date of install.	
250,C00K exhaust fan Model 135 Installed in	SACW F	2 Fully operational, 0-25% life expectancy used, no issues, no concerns	25 Years	10	\$3000.00	Fan exhausts the general area.	MODEL See Male See Ma
247,Water	F	3 Fully operational, 2-50% life expectancy used, periodic problems	15 Years	10		This building does not appear to have a water meter installed but is equipped with a pressure reducing valve.	

Electrical		

equipment	condition	Est remaining Service life	priority	cost	remarks &recommendations		
Equipment	Condition	Est. Remaining Service Life	Priority	Cost Estimate	Remarks & Recommendations		
253,Two - 37 1/2 KVA pole mounted transformers					Provides power to building through underground service. Transformers are maintained by power supplier. Disconnect on pole will be removed as the new service entrance is being currently installed. Maintained by power supplier.		
251,Kohler-80 KW LP Gas fired pad mounted generator Installed in 2000	3 Fully operational, 25-50% life expectancy used, periodic problems	15 Years	10	\$55,000		OHB 22	
						MUDEL Not SERIAL MARSH SPEC, 91-1034 SERVICE DUTY: TRACKY H.Z. 10 RPM-1000 FUEL 19 SINGLE PHASE VOLTAGE (200 (10) (10) (10) (10) (10) AMPS THREE PHASE VOLTAGE (200 (10) (10) (10) (10) (10) (10) AMPS TOTAGE (200 (10) (10) (10) (10) (10) (10) (10) AMPS TOTAGE (200 (10) (10) (10) (10) (10) (10) (10) GEN, MODEL SU (10) (10) (10) (10) (10) (10) GEN, MODEL SU (10) (10) (10) (10) (10) (10) (10) (10)	KOHLER MODEL FOR SEPILATION SPEC, 74-JULY SPEC, 74-JULY SPEC, 74-JULY HE SERVICE DUTY: BUCH HZ II FIPH: 180 FUEL U SINGLE PHASE THREE PHASE VOLTAGE VOLTA

equipment	condition	Est remaining Service life	priority	cost	remarks &recommendations		
						THERMAL-MAGNETIC CIRCUIT BREAK THE CONTROL SERVICE THE CONTROL SERVICE	
249,Electrical disconnect	1 Fully operational, new, recently replaced	25 + Years	10	\$2,000	Being installed during our visit.	ON OFF	
248,Ceiling hung 5 KW electric unit heater Make: Electromechanical Model: CI-5A Unknown date of install	4 Operational, 50- 75% life expectancy used, occasional problems, frequent repairs needed	5 Years	5	\$1,500	Maintains heat for this building. Recommend a second source of heat due to water in this building. A gas fired wall/floor mount heater that still produces heat during a power outage is preferable. Although this building is equipped with a generator the current electric heater could fail.	Electromode	ELECTROMODE AIR HEATER HIG. U.S. FAIL OFFICE S503-Z TYPE VOLTS 680 PHASE 3 CYCLE 60 KW'S 5 AMPS 6.1 AC MODEL GISSON NO. D35901 CLIMATE CONTROL DIV. THE SINGER CO. AUBURN, NEW YORK

equipment	condition	Est remaining Service life	priority	cost	remarks &recommendations	
246,Generator switchgear	2 Fully operational, 0-25% life expectancy used, no issues, no concerns	15 Years	10	\$5,000		

Site

No paved sidewalk or parking area around building. Access to the site is from a gravel drive off Pollards Mills Road near the intersection with Unity Road. Overall, gravel surfaces are in fair condition with the only recommended improvement to be re-grading the surface and adding additional gravel as necessary to level out the graded areas. If hard paving were planned for this site, such construction would likely require the installation of a full pavement box section including wearing surface, bituminous base, base course and subbase gravels, and possible catch basins/drainage structures.

Equipment	Condition	Est. Remaining Service Life	Priority	Cost Estimate	Remarks & Recommendations	Photos
859,Pavement	2	25	10	14,823 sq.ft Incl. drive	Pump station and gravel parking/access area. Access towards Pollards Mill Road.	